


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	WG1	WG2	WG3
May-21	974,000	741,489	252,278	248,726	240,485
Jun-21	714,000	707,606	237,423	237,814	232,369
Jul-21	566,000	393,393	134,849	129,596	128,948
Aug-21	514,000	411,193	140,054	135,185	135,954
Sep-21	716,000	957,296	328,228	316,256	312,812
Oct-21	1,051,000	805,356	280,398	266,167	258,791
Nov-21	1,224,000	1,149,191	399,017	380,196	369,978
Dec-21	1,217,000	1,256,121	428,605	416,086	411,430
Jan-22	1,343,000	1,090,541	289,562	405,135	395,844
Feb-22	1,133,000	1,172,040	402,121	396,163	373,756
Mar-22	1,312,000	1,490,987	504,716	495,732	490,539
Apr-22	1,272,000	1,288,755	442,083	425,015	421,657
May-22	974,000	967,486	331,022	319,660	316,804
Production 2022 (ytd) (kWh)	6,034,000	6,009,809	1,969,504	2,041,705	1,998,600
Total Production (kWh) (LTM)	12,036,000	11,689,965	3,918,078	3,923,005	3,848,882
Capacity Factor (LTM)	29.65%				

B. Site Energy Production Graph

May-2022



Monthly Report

May-2022

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
November-2022	Goldwind 4 Year Maintenance	~15	WG 1
November-2022	Goldwind 4 Year Maintenance	~15	WG 2
November-2022	Goldwind 4 Year Maintenance	~15	WG 3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
5/17/2022-5/18/2022	Goldwind 3.5 Year Maintenance	Planned	4.13	WG 1
5/17/2022-5/18/2022	Goldwind 3.5 Year Maintenance	Planned	3.47	WG 2
5/18/2022	Goldwind 3.5 Year Maintenance	Planned	1.00	WG 3

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
WG1	99.94%	97.95%
WG2	100.00%	100.00%
WG3	100.00%	99.66%
Avg	99.98%	99.20%

Downtime (hr)	This Month	Year To Date
WG1	9.88	224.89
WG2	8.48	100.19
WG3	4.33	121.93
Total	22.69	447.01

G. Billed Data

Meter Reading (Date/Time)	5/29/2022 12:00 AM
Meter To Date Produced	39,710,520 kWh
Meter To Date Consumed	142,686 kWh
Last Reading Produced	38,766,179 kWh
Last Reading Consumed	140,791 kWh
Billed kWh	942,446 kWh
Next Meter Reading	6/29/2022 12:00 AM

H. Report Notes and Comments