


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	L1	L2	L3
Jun-21	751,000	737,392	251,215	251,717	234,460
Jul-21	609,000	494,693	174,014	172,212	148,467
Aug-21	534,000	418,734	143,423	142,983	132,328
Sep-21	736,000	984,373	335,478	342,450	306,445
Oct-21	1,131,000	871,887	297,865	295,436	278,586
Nov-21	1,281,000	1,196,514	350,141	425,981	420,392
Dec-21	1,263,000	1,233,907	413,245	410,712	409,950
Jan-22	1,433,000	1,230,205	416,242	405,918	408,045
Feb-22	1,213,000	1,345,539	450,556	445,316	449,667
Mar-22	1,339,000	1,494,185	500,969	503,338	489,878
Apr-22	1,327,000	1,412,962	466,654	475,314	470,994
May-22	1,052,000	1,077,013	373,367	344,704	358,942
Jun-22	751,000	648,158	241,123	200,574	206,461
Production 2022 (ytd) (kWh)	7,115,000	7,208,062	2,448,911	2,375,164	2,383,987
Total Production (LTM) (kWh)	12,669,000	12,408,170	4,163,077	4,164,938	4,080,155
Capacity Factor (LTM)	31.48%				

B. Site Energy Production Graph

June-2022



Monthly Report

June-2022

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration	Turbine
		(hr)	
September-2022	Goldwind 2 Year Maintenance	~15	L1
September-2022	Goldwind 2 Year Maintenance	~15	L2
September-2022	Goldwind 2 Year Maintenance	~15	L3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration	Turbine
			(hrs)	
6/11/2022-6/13/2022	Turbine Fault	Unplanned	51.07	L2
6/16/2022-6/17/2022	Turbine Fault	Unplanned	17.58	L2
6/21/2022-6/22/2022	Turbine Fault	Unplanned	22.55	L2

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
L1	87.31%	97.88%
L2	100.00%	99.01%
L3	100.00%	100.00%
Avg	95.77%	98.96%

Downtime (hr)	This Month	Year To Date
L1	8.17	135.98
L2	98.90	283.73
L3	7.70	145.93
Total	114.77	565.64

G. Billed Data

Meter Reading (Date/Time)	6/25/2022 12:00 AM
Meter To Date Produced	22,865,706 kWh
Meter To Date Consumed	66,519 kWh
Last Reading Produced	22,147,599 kWh
Last Reading Consumed	63,718 kWh
Billed kWh	715,306 kWh
Next Meter Reading	7/27/2022 12:00 AM

H. Report Notes and Comments