


A. Site Energy Production Summary

|                              | Energy Production (kWh)   |                   |            |           |           |
|------------------------------|---------------------------|-------------------|------------|-----------|-----------|
|                              | Site                      |                   | By Turbine |           |           |
|                              | P50 (Expected Production) | Actual Production | Z4         | Z5        | Z6        |
| Jun-21                       | 637,000                   | 667,180           | 226,175    | 213,521   | 227,484   |
| Jul-21                       | 518,000                   | 423,089           | 144,295    | 141,912   | 136,882   |
| Aug-21                       | 448,000                   | 407,609           | 139,023    | 132,947   | 135,639   |
| Sep-21                       | 617,000                   | 957,074           | 321,730    | 316,478   | 318,866   |
| Oct-21                       | 956,000                   | 739,181           | 243,855    | 238,641   | 256,685   |
| Nov-21                       | 1,107,000                 | 1,150,429         | 384,301    | 366,844   | 399,284   |
| Dec-21                       | 1,098,000                 | 1,141,220         | 374,435    | 374,888   | 391,897   |
| Jan-22                       | 1,251,000                 | 1,253,751         | 420,362    | 406,883   | 426,506   |
| Feb-22                       | 1,044,000                 | 1,306,639         | 438,679    | 422,217   | 445,743   |
| Mar-22                       | 1,119,000                 | 1,335,480         | 443,031    | 438,839   | 453,610   |
| Apr-22                       | 1,116,000                 | 1,145,744         | 373,811    | 368,393   | 403,540   |
| May-22                       | 876,000                   | 984,712           | 298,460    | 333,446   | 352,806   |
| Jun-22                       | 637,000                   | 601,888           | 194,009    | 193,281   | 214,598   |
| Production 2022 (ytd) (kWh)  | 6,043,000                 | 6,628,214         | 2,168,352  | 2,163,059 | 2,296,803 |
| Total Production (kWh) (LTM) | 10,787,000                | 11,446,816        | 3,775,991  | 3,734,769 | 3,936,056 |
| Capacity Factor (LTM)        | 29.04%                    |                   |            |           |           |

B. Site Energy Production Graph

June-2022



Monthly Report  
June-2022

C. Safety Summary

|                        | This Month | Project Cumulative |
|------------------------|------------|--------------------|
| Recordable Incident(s) | 0          | 0                  |
| First Aid              | 0          | 1                  |

D. Planned Maintenance Events

| Date           | Event                       | Duration (hr) | Turbine |
|----------------|-----------------------------|---------------|---------|
| September-2022 | Goldwind 2 Year Maintenance | ~15           | Z4      |
| September-2022 | Goldwind 2 Year Maintenance | ~15           | Z5      |
| September-2022 | Goldwind 2 Year Maintenance | ~15           | Z6      |

E. Actual Maintenance Events

| Date                | Event            | Planned/Unplanned | Duration (hrs) | Turbine    |
|---------------------|------------------|-------------------|----------------|------------|
| 6/13/2022-6/14/2022 | Weather Shutdown | Unplanned         | 6.70           | Z4, Z5, Z6 |

F. Turbine Availability & Downtime

| Availability | This Month | Year To Date |
|--------------|------------|--------------|
| Z4           | 100.00%    | 99.99%       |
| Z5           | 100.00%    | 98.09%       |
| Z6           | 100.00%    | 99.85%       |
| Avg          | 100.00%    | 99.31%       |

| Downtime (hr) | This Month | Year To Date |
|---------------|------------|--------------|
| Z4            | 8.36       | 142.07       |
| Z5            | 8.36       | 210.69       |
| Z6            | 8.36       | 156.98       |
| Total         | 25.08      | 509.74       |

G. Billed Data

|                                    |                    |
|------------------------------------|--------------------|
| Meter Reading (Date/Time)          | 6/18/2022 12:00 AM |
| Ball 2.0 Production (This Period)  | 754,509 kWh        |
| Ball 2.0 Consumption (This Period) | 1,989 kWh          |
| Billed kWh                         | 752,520 kWh        |
| Next Meter Reading                 | 7/20/2022 12:00 AM |

H. Report Notes and Comments

\*March 2022 production includes estimates due to a SCADA server error.