


A. Site Energy Production Summary

	Energy Production (kWh)			
	Site		By Turbine	
	P50 (Expected Production)	Actual Production	W1	W2
Jun-21	425,000	479,735	244,261	235,474
Jul-21	390,000	298,836	152,425	146,411
Aug-21	399,000	297,535	152,628	144,907
Sep-21	337,000	665,033	337,170	327,863
Oct-21	637,000	518,984	262,835	256,149
Nov-21	834,000	849,882	425,765	424,117
Dec-21	1,015,000	821,418	415,630	405,788
Jan-22	875,000	857,334	429,640	427,694
Feb-22	917,000	861,229	467,908	393,321
Mar-22	802,000	991,707	500,106	491,601
Apr-22	951,000	795,380	402,642	392,738
May-22	601,000	614,219	307,353	306,866
Jun-22	425,000	413,887	205,685	208,202
Production 2022 (ytd) (kWh)	4,571,000	4,533,756	2,313,334	2,220,422
Total Production (kWh) (LTM)	8,183,000	7,985,444	4,059,787	3,925,657
Capacity Factor (LTM)	30.39%			

B. Site Energy Production Graph

June-2022



Monthly Report

June-2022

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
November-2022	Goldwind 7 Year Maintenance	~15	W1
November-2022	Goldwind 7 Year Maintenance	~15	W2

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
6/13/2022-6/14/2022	Weather Shutdown	Unplanned	6.71	W1, W2
6/18/2022-6/21/2022	Turbine Fault	Unplanned	50.16	W1

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
W1	93.03%	98.29%
W2	100.00%	99.99%
Avg	96.52%	99.14%

Downtime (hr)	This Month	Year To Date
W1	60.52	195.85
W2	8.89	184.95
Total	69.41	380.80

G. Billed Data

Meter Reading (Date/Time)	6/29/2022 12:00 AM
Meter To Date Produced	49,965,909 kWh
Meter To Date Consumed	97,673 kWh
Last Reading Produced	49,518,798 kWh
Last Reading Consumed	96,355 kWh
Billed kWh	445,793 kWh
Next Meter Reading	7/29/2022 12:00 AM

H. Report Notes and Comments