


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	L1	L2	L3
Jul-21	609,000	494,693	174,014	172,212	148,467
Aug-21	534,000	418,734	143,423	142,983	132,328
Sep-21	736,000	984,373	335,478	342,450	306,445
Oct-21	1,131,000	871,887	297,865	295,436	278,586
Nov-21	1,281,000	1,196,514	350,141	425,981	420,392
Dec-21	1,263,000	1,233,907	413,245	410,712	409,950
Jan-22	1,433,000	1,230,205	416,242	405,918	408,045
Feb-22	1,213,000	1,345,539	450,556	445,316	449,667
Mar-22	1,339,000	1,494,185	500,969	503,338	489,878
Apr-22	1,327,000	1,412,962	466,654	475,314	470,994
May-22	1,052,000	1,077,013	373,367	344,704	358,942
Jun-22	751,000	648,158	241,123	200,574	206,461
Jul-22	609,000	601,624	214,570	198,293	188,761
Production 2022 (ytd) (kWh)	7,724,000	7,809,686	2,663,481	2,573,457	2,572,748
Total Production (LTM) (kWh)	12,669,000	12,515,101	4,203,633	4,191,019	4,120,449
Capacity Factor (LTM)	31.75%				

B. Site Energy Production Graph

July-2022



Monthly Report

July-2022

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
September-2022	Goldwind 2 Year Maintenance	~15	L1
September-2022	Goldwind 2 Year Maintenance	~15	L2
September-2022	Goldwind 2 Year Maintenance	~15	L3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
7/1/2022-7/2/2022	Turbine Fault	Unplanned	14.69	L2
7/5/2022-7/6/2022	Turbine Fault	Unplanned	22.13	L2
7/11/2022	Turbine Fault	Unplanned	8.72	L3
7/26/2022	Substation Work	Planned	6.42	L1,L2,L3

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
L1	99.94%	98.18%
L2	95.05%	98.44%
L3	98.83%	99.83%
Avg	97.94%	98.82%

Downtime (hr)	This Month	Year To Date
L1	13.34	149.32
L2	49.69	333.42
L3	21.59	167.52
Total	84.62	650.26

G. Billed Data

Meter Reading (Date/Time)	7/27/2022 12:00 AM
Meter To Date Produced	23,508,700 kWh
Meter To Date Consumed	70,893 kWh
Last Reading Produced	22,865,706 kWh
Last Reading Consumed	66,519 kWh
Billed kWh	638,620 kWh
Next Meter Reading	8/25/2022 12:00 AM

H. Report Notes and Comments