


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	W1	W2	W3
Jul-21	527,000	318,063	107,885	100,155	110,023
Aug-21	449,000	324,019	109,256	105,233	109,530
Sep-21	610,000	740,131	243,253	241,498	255,380
Oct-21	990,000	693,360	241,616	219,829	231,915
Nov-21	1,123,000	976,482	349,225	311,053	316,204
Dec-21	1,153,000	1,088,213	372,080	354,578	361,555
Jan-22	1,306,000	845,320	315,868	177,718	351,734
Feb-22	1,137,000	1,182,964	407,437	382,881	392,646
Mar-22	1,134,000	1,341,048	444,624	443,527	452,897
Apr-22	1,176,000	1,079,664	374,895	351,597	353,172
May-22	927,000	861,830	293,507	271,102	297,221
Jun-22	634,000	512,159	167,043	167,623	177,493
Jul-22	527,000	418,863	139,334	134,326	145,203
Production 2022 (ytd) (kWh)	6,841,000	6,241,848	2,142,708	1,928,774	2,170,366
Total Production (kWh) (LTM)	11,166,000	10,064,053	3,458,138	3,160,965	3,444,950
Capacity Factor (LTM)	25.53%				

B. Site Energy Production Graph

July-2022



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	1

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
October-2022	Goldwind 5 Year Maintenance	~15	W1
October-2022	Goldwind 5 Year Maintenance	~15	W2
October-2022	Goldwind 5 Year Maintenance	~15	W3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
7/29/2022-7/30/2022	Turbine Fault	Unplanned	18.57	W1

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
W1	97.19%	98.91%
W2	99.97%	99.68%
W3	99.97%	99.95%
Avg	99.04%	99.51%

Downtime (hr)	This Month	Year To Date
W1	23.12	295.87
W2	2.42	476.65
W3	2.41	248.57
Total	27.95	1021.09

G. Billed Data

Meter Reading (Date/Time)	7/21/2022 12:00 AM
Meter To Date Produced	43,779,399 kWh
Meter To Date Consumed	131,136 kWh
Last Reading Produced	43,357,556 kWh
Last Reading Consumed	127,389 kWh
Billed kWh	418,096 kWh
Next Meter Reading	8/21/2022 12:00 AM

H. Report Notes and Comments