



HARPSTER WIND PROJECT


Harpster, OH

A. Site Energy Production Summary

	Energy Production (kWh)	
	Site	
	P50 (Expected Production)	Actual Production
Aug-21	157,000	116,887
Sep-21	224,000	257,547
Oct-21	338,000	223,963
Nov-21	402,000	354,559
Dec-21	403,000	348,906
Jan-22	460,000	378,784
Feb-22	372,000	422,162
Mar-22	417,000	465,731
Apr-22	399,000	374,215
May-22	311,000	282,400
Jun-22	228,000	182,539
Jul-22	179,000	154,343
Aug-22	157,000	131,637
Production 2022 (ytd) (kWh)	2,523,000	2,391,811
Total Production (kWh) (LTM)	3,890,000	3,576,786
Capacity Factor (LTM)	27.22%	

B. Site Energy Production Graph

August-2022



Monthly Report

August-2022



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
October-2022	Goldwind 6.5 Year Maintenance	~8	H1

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
------	-------	-------------------	----------------	---------

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
H1	100.00%	99.88%
Downtime (hr)	This Month	Year To Date
H1	6.53	72.45

G. Billed Data

Meter Reading (Date/Time)	8/25/2022 12:00 AM
Meter To Date Produced	21,534,713 kWh
Meter To Date Consumed	71,585 kWh
Last Reading Produced	21,426,026 kWh
Last Reading Consumed	70,476 kWh
Billed kWh	107,578 kWh
Next Meter Reading	9/24/2022 12:00 AM

H. Report Notes and Comments