


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	Z4	Z5	Z6
Aug-21	448,000	407,609	139,023	132,947	135,639
Sep-21	617,000	957,074	321,730	316,478	318,866
Oct-21	956,000	739,181	243,855	238,641	256,685
Nov-21	1,107,000	1,150,429	384,301	366,844	399,284
Dec-21	1,098,000	1,141,220	374,435	374,888	391,897
Jan-22	1,251,000	1,253,751	420,362	406,883	426,506
Feb-22	1,044,000	1,306,639	438,679	422,217	445,743
Mar-22	1,119,000	1,335,480	443,031	438,839	453,610
Apr-22	1,116,000	1,145,744	373,811	368,393	403,540
May-22	876,000	984,712	298,460	333,446	352,806
Jun-22	637,000	601,888	194,009	193,281	214,598
Jul-22	518,000	586,264	192,973	189,924	203,367
Aug-22	448,000	459,360	146,939	148,700	163,721
Production 2022 (ytd) (kWh)	7,009,000	7,673,838	2,508,264	2,501,683	2,663,891
Total Production (kWh) (LTM)	10,787,000	11,661,742	3,832,585	3,798,534	4,030,623
Capacity Factor (LTM)	29.58%				

B. Site Energy Production Graph

August-2022



Monthly Report
August-2022

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	1

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
September-2022	Goldwind 2 Year Maintenance	~15	Z4
September-2022	Goldwind 2 Year Maintenance	~15	Z5
September-2022	Goldwind 2 Year Maintenance	~15	Z6

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
8/2/2022	Turbine Fault	Unplanned	4.33	Z5

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
Z4	100.00%	99.99%
Z5	99.42%	98.26%
Z6	100.00%	99.89%
Avg	99.81%	99.38%

Downtime (hr)	This Month	Year To Date
Z4	1.3	143.99
Z5	5.63	231.09
Z6	1.3	158.90
Total	8.23	533.98

G. Billed Data

Meter Reading (Date/Time)	8/18/2022 12:00 AM
Ball 2.0 Production (This Period)	541,482 kWh
Ball 2.0 Consumption (This Period)	2,813 kWh
Billed kWh	538,669 kWh
Next Meter Reading	9/17/2022 12:00 AM

H. Report Notes and Comments

*March 2022 production includes estimates due to a SCADA server error.