


A. Site Energy Production Summary

	Energy Production (kWh)	
	Site	
	P50 (Expected Production)	Actual Production
Aug-21	211,000	138,271
Sep-21	182,000	352,762
Oct-21	341,000	280,589
Nov-21	445,000	429,438
Dec-21	537,000	446,947
Jan-22	455,000	449,235
Feb-22	478,000	481,534
Mar-22	422,000	515,661
Apr-22	499,000	459,204
May-22	318,000	366,781
Jun-22	222,000	230,391
Jul-22	201,000	220,456
Aug-22	211,000	178,498
Production 2022 (ytd) (kWh)	2,806,000	2,901,760
Total Production (LTM) (kWh)	4,311,000	4,411,496
Capacity Factor (LTM)	33.57%	

B. Site Energy Production Graph

August-2022



Monthly Report
August-2022

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
October-2022	Goldwind 4.5 Year Maintenance	~8	W1

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
------	-------	-------------------	----------------	---------

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
W1	100.00%	99.98%
Downtime (hr)	This Month	Year To Date
W1	1.50	150.97

G. Billed Data

Meter Reading (Date/Time)	9/1/2022 12:00 AM
Meter To Date Produced	18,098,387 kWh
Meter To Date Consumed	80,405 kWh
Last Reading Produced	17,922,973 kWh
Last Reading Consumed	78,175 kWh
Billed kWh	173,184 kWh
Next Meter Reading	10/1/2022 12:00 AM

H. Report Notes and Comments