

A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	WG1	WG2	WG3
Aug-21	514,000	411,193	140,054	135,185	135,954
Sep-21	716,000	957,296	328,228	316,256	312,812
Oct-21	1,051,000	805,356	280,398	266,167	258,791
Nov-21	1,224,000	1,149,191	399,017	380,196	369,978
Dec-21	1,217,000	1,256,121	428,605	416,086	411,430
Jan-22	1,343,000	1,090,541	289,562	405,135	395,844
Feb-22	1,133,000	1,172,040	402,121	396,163	373,756
Mar-22	1,312,000	1,490,987	504,716	495,732	490,539
Apr-22	1,272,000	1,288,755	442,083	425,015	421,657
May-22	974,000	967,486	331,022	319,660	316,804
Jun-22	714,000	591,297	204,680	194,977	191,640
Jul-22	566,000	501,161	169,673	169,616	161,872
Aug-22	514,000	462,848	160,121	151,764	150,963
Production 2022 (ytd) (kWh)	7,828,000	7,565,115	2,503,978	2,558,062	2,503,075
Total Production (kWh) (LTM)	12,036,000	11,733,079	3,940,226	3,936,767	3,856,086
Capacity Factor (LTM)	29.76%				

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events


Date	Event	Duration (hr)	Turbine
November-2022	Goldwind 4 Year Maintenance	~15	WG 1
November-2022	Goldwind 4 Year Maintenance	~15	WG 2
November-2022	Goldwind 4 Year Maintenance	~15	WG 3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
------	-------	-------------------	----------------	---------

B. Site Energy Production Graph

August-2022



F. Turbine Availability & Downtime

Availability	This Month	Year To Date
WG1	100.00%	98.52%
WG2	100.00%	100.00%
WG3	100.00%	99.17%
Avg	100.00%	99.23%

Downtime (hr)	This Month	Year To Date
WG1	4.82	252.59
WG2	7.44	118.48
WG3	5.54	175.31
Total	17.80	546.38

G. Billed Data

Meter Reading (Date/Time)	8/29/2022 12:00 AM
Meter To Date Produced	41,280,307 kWh
Meter To Date Consumed	155,368 kWh
Last Reading Produced	40,875,381 kWh
Last Reading Consumed	150,181 kWh
Billed kWh	399,739 kWh
Next Meter Reading	9/29/2022 12:00 AM

H. Report Notes and Comments