


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	L1	L2	L3
Oct-21	1,131,000	871,887	297,865	295,436	278,586
Nov-21	1,281,000	1,196,514	350,141	425,981	420,392
Dec-21	1,263,000	1,233,907	413,245	410,712	409,950
Jan-22	1,433,000	1,230,205	416,242	405,918	408,045
Feb-22	1,213,000	1,345,539	450,556	445,316	449,667
Mar-22	1,339,000	1,494,185	500,969	503,338	489,878
Apr-22	1,327,000	1,412,962	466,654	475,314	470,994
May-22	1,052,000	1,077,013	373,367	344,704	358,942
Jun-22	751,000	648,158	241,123	200,574	206,461
Jul-22	609,000	601,624	214,570	198,293	188,761
Aug-22	534,000	495,062	174,285	161,531	159,246
Sep-22	736,000	590,681	207,671	205,644	177,366
Oct-22	1,131,000	1,314,977	441,919	437,021	436,037
Production 2022 (ytd) (kWh)	10,125,000	10,210,406	3,487,356	3,377,653	3,345,397
Total Production (LTM) (kWh)	12,669,000	12,640,827	4,250,742	4,214,346	4,175,739
Capacity Factor (LTM)	32.07%				

B. Site Energy Production Graph

October-2022



Monthly Report
October-2022

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
April-2023	Goldwind 2.5 Year Maintenance	~8	L1
April-2023	Goldwind 2.5 Year Maintenance	~8	L2
April-2023	Goldwind 2.5 Year Maintenance	~8	L3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
10/4/2022	Goldwind 2 Year Maintenance	Planned	5.16	L2
10/6/2022	Goldwind 2 Year Maintenance	Planned	4.53	L3
10/17/2022	Goldwind 2 Year Maintenance	Planned	2.05	L3

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
L1	100.00%	98.72%
L2	100.00%	98.63%
L3	100.00%	99.53%
Avg	100.00%	98.96%

Downtime (hr)	This Month	Year To Date
L1		155.57
L2	5.16	361.40
L3	6.58	201.52
Total	11.74	718.49

G. Billed Data

Meter Reading (Date/Time)	10/25/2022 12:00 AM
Meter To Date Produced	25,757,014 kWh
Meter To Date Consumed	81,992 kWh
Last Reading Produced	24,421,786 kWh
Last Reading Consumed	80,613 kWh
Billed kWh	1,333,849 kWh
Next Meter Reading	11/23/2022 12:00 AM

H. Report Notes and Comments