


A. Site Energy Production Summary

	Energy Production (kWh)	
	Site	
	P50 (Expected Production)	Actual Production
Oct-21	341,000	280,589
Nov-21	445,000	429,438
Dec-21	537,000	446,947
Jan-22	455,000	449,235
Feb-22	478,000	481,534
Mar-22	422,000	515,661
Apr-22	499,000	459,204
May-22	318,000	366,781
Jun-22	222,000	230,391
Jul-22	201,000	220,456
Aug-22	211,000	178,498
Sep-22	182,000	210,137
Oct-22	341,000	453,178
Production 2022 (ytd) (kWh)	3,329,000	3,565,075
Total Production (LTM) (kWh)	4,311,000	4,441,460
Capacity Factor (LTM)	33.80%	

B. Site Energy Production Graph

October-2022



Monthly Report
October-2022

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
April-2023	Goldwind 5 Year Maintenance	~8	W1

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
10/14/2022	Goldwind 4.5 Year Maintenance	Planned	3.49	W1

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
W1	100.00%	99.98%
Downtime (hr)	This Month	Year To Date
W1	4.55	155.52

G. Billed Data

Meter Reading (Date/Time)	11/1/2022 12:00 AM
Meter To Date Produced	18,751,651 kWh
Meter To Date Consumed	82,495 kWh
Last Reading Produced	18,304,938 kWh
Last Reading Consumed	81,751 kWh
Billed kWh	445,969 kWh
Next Meter Reading	12/1/2022 12:00 AM

H. Report Notes and Comments