

A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	Expected Production	Actual Production	WTG 1	WTG 2	WTG 3
Nov-21	1,362,692	1,409,993	478,180	445,587	486,226
Dec-21	1,254,397	1,331,608	397,271	459,909	474,428
Jan-22	1,290,968	1,353,578	462,516	440,464	450,598
Feb-22	1,170,349	1,604,544	545,081	532,075	527,388
Mar-22	1,227,217	1,638,719	558,009	535,925	544,785
Apr-22	1,438,497	1,509,431	506,692	498,089	504,650
May-22	980,450	1,209,327	409,133	403,329	396,865
Jun-22	649,158	765,507	272,227	239,819	253,461
Jul-22	618,687	617,049	214,843	198,590	203,616
Aug-22	559,508	531,092	179,942	168,860	182,290
Sep-22	603,085	395,973	133,364	128,586	134,023
Oct-22	967,926	1,373,420	466,421	429,871	477,128
Nov-22	1,362,692	1,568,093	527,267	521,360	519,466
Production 2022 (ytd) (kWh)	10,868,538	12,566,733	4,275,495	4,096,968	4,194,270
Total Production (LTM) (kWh)	12,122,935	13,898,341	4,672,766	4,556,877	4,668,698
Capacity Factor (LTM)	35.26%				

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events


Date	Event	Duration (hr)	Turbine
April-2023	Goldwind 10.5 Year Maintenance	~8	WTG 1
April-2023	Goldwind 10.5 Year Maintenance	~8	WTG 2
April-2023	Goldwind 10.5 Year Maintenance	~8	WTG 3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
------	-------	-------------------	----------------	---------

B. Site Energy Production Graph

November-2022



F. Turbine Availability & Downtime

Availability	This Month	Year To Date
WTG 1	100.00%	99.96%
WTG 2	99.75%	99.61%
WTG 3	99.16%	99.61%
Avg	99.64%	99.72%

Downtime (hr)	This Month	Year To Date
WTG 1	0.00	184.55
WTG 2	1.80	227.90
WTG 3	6.07	201.26
Total	7.87	613.71

G. Wind Speed & Capacity Factor

Wind Speed (mph)	This Month	2022 Annual
WTG 1	15.17	13.24
WTG 2	15.08	13.07
WTG 3	15.57	13.39
Estimated	15.58	13.39

Capacity Factor (%)	This Month	2022 Annual
WTG 1	48.82%	35.56%
WTG 2	48.27%	34.18%
WTG 3	48.10%	34.99%
Low Estimate	41.95%	28.72%

H. Report Notes and Comments

* September 2022 production is lower than actual due to SCADA commuication issues.

**November 2022 downtime numbers are under review and will be confirmed in the December 2022 report.