




A. Site Energy Production Summary

	Energy Production (kWh)					
	Site		By Turbine			
	Expected Production	Actual Production	WTG A	WTG B	WTG C	
Nov-21	1,395,914	1,321,032	440,344	440,344	440,344	*
Dec-21	1,278,858	1,140,578	380,193	380,193	380,193	*
Jan-22	1,332,437	1,208,008	402,669	402,669	402,669	*
Feb-22	1,157,019	1,484,937	494,979	494,979	494,979	*
Mar-22	1,242,761	1,521,120	507,040	507,040	507,040	*
Apr-22	1,447,248	1,416,441	472,147	472,147	472,147	*
May-22	1,010,966	1,163,565	387,855	387,855	387,855	*
Jun-22	668,411	700,770	233,590	233,590	233,590	*
Jul-22	638,097	555,748	233,590	233,590	233,590	*
Aug-22	577,992	280,279	55,330	81,647	143,302	**
Sep-22	631,697	677,002	239,176	217,343	220,483	
Oct-22	1,003,602	1,496,092	512,714	497,365	486,013	
Nov-22	1,395,914	1,515,960	520,077	499,774	496,109	
Production 2022 (ytd) (kWh)	11,106,141	12,019,923	4,059,168	4,028,000	4,077,778	
Total Production (kWh) (LTM)	12,384,999	13,160,501	4,439,360	4,408,192	4,457,970	
Capacity Factor (LTM)	33.39%					

B. Site Energy Production Graph

November-2022



Monthly Report
November-2022

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
April-2023	Goldwind 10.5 Year Maintenance	~8	WTG A
April-2023	Goldwind 10.5 Year Maintenance	~8	WTG B
April-2023	Goldwind 10.5 Year Maintenance	~8	WTG C

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
11/8/2022	Turbine Fault	Unplanned	11.25	WTG C

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
WTG A	100.00%	99.86%
WTG B	100.00%	99.43%
WTG C	98.34%	98.24%
Avg	99.45%	99.17%

Downtime (hr)	This Month	Year To Date
WTG A	0	11.63
WTG B	0	30.09
WTG C	11.94	134.07
Total	11.94	175.79

G. Wind Speed & Capacity Factor

Wind Speed (mph)	This Month	2022 Annual
WTG A	14.55	11.95
WTG B	14.12	11.49
WTG C	15.27	12.39
Estimated	15.58	13.39

Capacity Factor (%)	This Month	2022 Annual
WTG A	48.16%	30.22%
WTG B	46.28%	29.51%
WTG C	45.94%	30.64%
Low Estimate	41.95%	28.72%

H. Report Notes and Comments

*Production read from the meter due to communication issues and will be updated if SCADA data becomes available. Total metered production divided to estimate per turbine total.

** August 2022 production is lower than actual due to SCADA communication issues.