


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	L1	L2	L3
Nov-21	1,281,000	1,196,514	350,141	425,981	420,392
Dec-21	1,263,000	1,233,907	413,245	410,712	409,950
Jan-22	1,433,000	1,230,205	416,242	405,918	408,045
Feb-22	1,213,000	1,345,539	450,556	445,316	449,667
Mar-22	1,339,000	1,494,185	500,969	503,338	489,878
Apr-22	1,327,000	1,412,962	466,654	475,314	470,994
May-22	1,052,000	1,077,013	373,367	344,704	358,942
Jun-22	751,000	648,158	241,123	200,574	206,461
Jul-22	609,000	601,624	214,570	198,293	188,761
Aug-22	534,000	495,062	174,285	161,531	159,246
Sep-22	736,000	590,681	207,671	205,644	177,366
Oct-22	1,131,000	1,314,977	441,919	437,021	436,037
Nov-22	1,281,000	1,358,321	450,327	452,535	455,459
Production 2022 (ytd) (kWh)	11,406,000	11,568,727	3,937,683	3,830,188	3,800,856
Total Production (LTM) (kWh)	12,669,000	12,802,634	4,350,928	4,240,900	4,210,806
Capacity Factor (LTM)	32.48%				

B. Site Energy Production GraphNovember-2022



Monthly ReportNovember-2022

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
April-2023	Goldwind 2.5 Year Maintenance	~8	L1
April-2023	Goldwind 2.5 Year Maintenance	~8	L2
April-2023	Goldwind 2.5 Year Maintenance	~8	L3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
------	-------	-------------------	----------------	---------

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
L1	100.00%	98.84%
L2	100.00%	98.75%
L3	100.00%	99.57%
Avg	100.00%	99.05%

Downtime (hr)	This Month	Year To Date
L1	1.00	156.57
L2	0.83	362.23
L3	1.03	202.55
Total	2.86	721.35

G. Billed Data

Meter Reading (Date/Time)	11/23/2022 12:00 AM
Meter To Date Produced	26,965,316 kWh
Meter To Date Consumed	83,806 kWh
Last Reading Produced	25,757,014 kWh
Last Reading Consumed	81,992 kWh
Billed kWh	1,206,488 kWh
Next Meter Reading	12/28/2022 12:00 AM

H. Report Notes and Comments