


A. Site Energy Production Summary

	Energy Production (kWh)			
	Site		By Turbine	
	P50 (Expected Production)	Actual Production	V1	V2
Nov-21	796,000	791,404	397,996	393,408
Dec-21	820,000	763,656	384,433	379,223
Jan-22	931,000	817,296	405,482	411,814
Feb-22	737,000	838,853	421,431	417,422
Mar-22	777,000	942,768	455,809	486,959
Apr-22	722,000	794,963	403,811	391,152
May-22	564,000	648,467	329,704	318,763
Jun-22	422,000	414,874	202,214	212,660
Jul-22	351,000	385,489	190,281	195,208
Aug-22	303,000	297,191	147,920	149,271
Sep-22	431,000	383,178	188,508	194,670
Oct-22	674,000	770,712	390,964	379,748
Nov-22	796,000	889,743	458,319	431,424
Production 2022 (ytd) (kWh)	6,708,000	7,183,534	3,594,443	3,589,091
Total Production (LTM) (kWh)	7,528,000	7,947,190	3,978,876	3,968,314
Capacity Factor (LTM)	30.24%			

B. Site Energy Production Graph

November-2022



Monthly Report

November-2022

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	1

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
May-2023	Goldwind 4.5 Year Maintenance	~8	V1
May-2023	Goldwind 4.5 Year Maintenance	~8	V2

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
11/2/2022	Goldwind 4 Year Maintenance	Planned	5.24	V1
11/3/2022	Goldwind 4 Year Maintenance	Planned	4.84	V2

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
V1	100.00%	99.52%
V2	99.82%	99.68%
Avg	99.91%	99.60%

Downtime (hr)	This Month	Year To Date
V1	8.36	168.14
V2	9.25	155.89
Total	17.61	324.03

G. Billed Data

Meter Reading (Date/Time)	12/1/2022 12:00 AM
Meter To Date Produced	30,524,473 kWh
Meter To Date Consumed	76,484 kWh
Last Reading Produced	29,663,474 kWh
Last Reading Consumed	75,807 kWh
Billed kWh	860,322 kWh
Next Meter Reading	1/1/2023 12:00 AM

H. Report Notes and Comments