


A. Site Energy Production Summary

	Energy Production (kWh)	
	Site	
	P50 (Expected Production)	Actual Production
Nov-21	445,000	429,438
Dec-21	537,000	446,947
Jan-22	455,000	449,235
Feb-22	478,000	481,534
Mar-22	422,000	515,661
Apr-22	499,000	459,204
May-22	318,000	366,781
Jun-22	222,000	230,391
Jul-22	201,000	220,456
Aug-22	211,000	178,498
Sep-22	182,000	210,137
Oct-22	341,000	453,178
Nov-22	445,000	483,244
Production 2022 (ytd) (kWh)	3,774,000	4,048,319
Total Production (LTM) (kWh)	4,311,000	4,495,266
Capacity Factor (LTM)	34.21%	

B. Site Energy Production Graph

November-2022



Monthly Report
November-2022

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
April-2023	Goldwind 5 Year Maintenance	~15	W1

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
11/27/2022	Turbine Fault	Unplanned	12.62	W1
11/28/2022	Turbine Fault	Unplanned	7.10	W1

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
W1	96.91%	99.70%
Downtime (hr)	This Month	Year To Date
W1	22.27	177.79

G. Billed Data

Meter Reading (Date/Time)	12/1/2022 12:00 AM
Meter To Date Produced	19,227,454 kWh
Meter To Date Consumed	83,246 kWh
Last Reading Produced	18,751,651 kWh
Last Reading Consumed	82,495 kWh
Billed kWh	475,052 kWh
Next Meter Reading	1/1/2023 12:00 AM

H. Report Notes and Comments