



HARPSTER WIND PROJECT


Harpster, OH

A. Site Energy Production Summary

	Energy Production (kWh)	
	Site	
	P50 (Expected Production)	Actual Production
Dec-21	403,000	348,906
Jan-22	460,000	378,784
Feb-22	372,000	422,162
Mar-22	417,000	465,731
Apr-22	399,000	374,215
May-22	311,000	282,400
Jun-22	228,000	182,539
Jul-22	179,000	154,343
Aug-22	157,000	131,637
Sep-22	224,000	180,602
Oct-22	338,000	363,631
Nov-22	402,000	396,713
Dec-22	403,000	314,804
Production 2022 (ytd) (kWh)	3,890,000	3,647,561
Total Production (kWh) (LTM)	3,890,000	3,647,561
Capacity Factor (LTM)	27.76%	

B. Site Energy Production Graph

December-2022



Monthly Report

December-2022



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
April-2023	Goldwind 7 Year Maintenance	~15	H1

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
12/18/2022-12/19/2022	Turbine Fault	Unplanned	19.73	H1
12/23/2022-12/24/2022	Weather Shutdown	Unplanned	31.64	H1

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
H1	97.34%	99.60%
Downtime (hr)	This Month	Year To Date
H1	52.77	149.24

G. Billed Data

Meter Reading (Date/Time)	12/28/2022 12:00 AM
Meter To Date Produced	22,733,226 kWh
Meter To Date Consumed	74,355 kWh
Last Reading Produced	22,384,480 kWh
Last Reading Consumed	73,281 kWh
Billed kWh	347,672 kWh
Next Meter Reading	1/27/2023 12:00 AM

H. Report Notes and Comments