


A. Site Energy Production Summary

	Energy Production (kWh)			
	Site		By Turbine	
	P50 (Expected Production)	Actual Production	V1	V2
Dec-21	820,000	763,656	384,433	379,223
Jan-22	931,000	817,296	405,482	411,814
Feb-22	737,000	838,853	421,431	417,422
Mar-22	777,000	942,768	455,809	486,959
Apr-22	722,000	794,963	403,811	391,152
May-22	564,000	648,467	329,704	318,763
Jun-22	422,000	414,874	202,214	212,660
Jul-22	351,000	385,489	190,281	195,208
Aug-22	303,000	297,191	147,920	149,271
Sep-22	431,000	383,178	188,508	194,670
Oct-22	674,000	770,712	390,964	379,748
Nov-22	796,000	889,743	458,319	431,424
Dec-22	820,000	853,742	430,989	422,753
Production 2022 (ytd) (kWh)	7,528,000	8,037,276	4,025,432	4,011,844
Total Production (LTM) (kWh)	7,528,000	8,037,276	4,025,432	4,011,844
Capacity Factor (LTM)	30.58%			

B. Site Energy Production Graph



Monthly Report

December-2022

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	1

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
May-2023	Goldwind 4.5 Year Maintenance	~8	V1
May-2023	Goldwind 4.5 Year Maintenance	~8	V2

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
------	-------	-------------------	----------------	---------

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
V1	100.00%	99.56%
V2	100.00%	99.71%
Avg	100.00%	99.63%

Downtime (hr)	This Month	Year To Date
V1	-	168.14
V2	-	155.89
Total	-	324.03

G. Billed Data

Meter Reading (Date/Time)	1/1/2023 12:00 AM
Meter To Date Produced	31,356,739 kWh
Meter To Date Consumed	78,023 kWh
Last Reading Produced	30,524,473 kWh
Last Reading Consumed	76,484 kWh
Billed kWh	830,727 kWh
Next Meter Reading	2/1/2023 12:00 AM

H. Report Notes and Comments