


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	L1	L2	L3
Jan-22	1,433,000	1,230,205	416,242	405,918	408,045
Feb-22	1,213,000	1,345,539	450,556	445,316	449,667
Mar-22	1,339,000	1,494,185	500,969	503,338	489,878
Apr-22	1,327,000	1,412,962	466,654	475,314	470,994
May-22	1,052,000	1,077,013	373,367	344,704	358,942
Jun-22	751,000	648,158	241,123	200,574	206,461
Jul-22	609,000	601,624	214,570	198,293	188,761
Aug-22	534,000	495,062	174,285	161,531	159,246
Sep-22	736,000	590,681	207,671	205,644	177,366
Oct-22	1,131,000	1,314,977	441,919	437,021	436,037
Nov-22	1,281,000	1,358,321	450,327	452,535	455,459
Dec-22	1,263,000	1,435,227	471,526	479,772	483,929
Jan-23	1,433,000	1,025,974	346,845	343,212	335,917
Production 2022 (ytd) (kWh)	1,433,000	1,025,974	346,845	343,212	335,917
Total Production (LTM) (kWh)	12,669,000	12,799,723	4,339,812	4,247,254	4,212,657
Capacity Factor (LTM)	32.47%				

B. Site Energy Production Graph

January-2023



Monthly Report
January-2023

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
April-2023	Goldwind 2.5 Year Maintenance	~8	L1
April-2023	Goldwind 2.5 Year Maintenance	~8	L2
April-2023	Goldwind 2.5 Year Maintenance	~8	L3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
1/13/2023-1/14/2023	Customer Maintenance	Unplanned	27.72	L1, L2, L3
1/22/2023-1/23/2023	Turbine Fault	Unplanned	13.97	L3
1/30/2023	Weather Shutdown	Unplanned	6.03	L1, L2, L3

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
L1	100.00%	100.00%
L2	100.00%	100.00%
L3	98.12%	98.12%
Avg	99.37%	99.37%

Downtime (hr)	This Month	Year To Date
L1	33.75	33.75
L2	33.75	33.75
L3	47.72	47.72
Total	115.22	115.22

G. Billed Data

Meter Reading (Date/Time)	1/27/2023 12:00 AM
Meter To Date Produced	29,558,809 kWh
Meter To Date Consumed	89,501 kWh
Last Reading Produced	28,456,161 kWh
Last Reading Consumed	86,325 kWh
Billed kWh	1,099,472 kWh
Next Meter Reading	2/25/2023 12:00 AM

H. Report Notes and Comments