



BALL CORPORATION - ZEPHYR WIND PROJECT 1.0

North Findlay Wind Campus, Findlay, OH

Monthly Report

January-2023




A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	Z1	Z2	Z3
Jan-22	1,260,000	1,252,569	435,949	420,553	396,067
Feb-22	1,310,000	1,354,099	469,778	464,716	419,606
Mar-22	1,140,000	1,356,275	481,385	457,802	417,088
Apr-22	1,359,000	1,267,232	435,279	427,907	404,046
May-22	856,000	899,215	304,468	311,170	283,577
Jun-22	599,000	572,841	206,791	192,580	173,470
Jul-22	549,000	552,201	195,618	183,810	172,773
Aug-22	559,000	437,708	156,192	146,109	135,407
Sep-22	482,000	520,541	181,453	173,959	165,128
Oct-22	916,000	1,182,514	413,378	402,621	366,515
Nov-22	1,203,000	1,382,132	482,159	467,912	432,061
Dec-22	1,475,000	1,306,656	455,817	444,843	405,996
Jan-23	1,260,000	1,026,487	349,179	349,947	327,361
Production 2023 (ytd) (kWh)	1,260,000	1,026,487	349,179	349,947	327,361
Total Production (LTM) (kWh)	11,708,000	11,857,901	4,131,497	4,023,376	3,703,028
Capacity Factor (LTM)	30.08%				

B. Site Energy Production Graph

January-2023



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
April-2023	Goldwind 7 Year Maintenance	~15	Z1
April-2023	Goldwind 7 Year Maintenance	~15	Z2
April-2023	Goldwind 7 Year Maintenance	~15	Z3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
1/30/2023	Weather Shutdown	Unplanned	6.80	Z1
1/30/2023	Weather Shutdown	Unplanned	6.82	Z2
1/30/2023	Weather Shutdown	Unplanned	7	Z3

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
Z1	100.00%	100.00%
Z2	100.00%	100.00%
Z3	99.97%	99.97%
Avg	99.99%	99.99%

Downtime (hr)	This Month	Year To Date
Z1	7.77	7.77
Z2	7.96	7.96
Z3	8.17	8.17
Total	23.90	23.90

G. Billed Data

Meter Reading (Date/Time)	1/20/2023 12:00 AM
Ball 1.0 Production (This Period)	1,376,882 kWh
Ball 1.0 Consumption (This Period)	1,171 kWh
Billed kWh	975,340 kWh
Next Meter Reading	2/18/2023 12:00 AM

H. Report Notes and Comments

* February 2022 production includes estimates due to a SCADA server error.

**April 2022 production includes estimates due to a SCADA server error.

***September 2022 production includes estimates due to a SCADA server error.