




Monthly Report
April-2023

A. Site Energy Production Summary

	Energy Production (kWh)					
	Site		By Turbine			
	Expected Production	Actual Production	WTG A	WTG B	WTG C	
Apr-22	1,447,248	1,416,441	472,147	472,147	472,147	*
May-22	1,010,966	1,163,565	387,855	387,855	387,855	*
Jun-22	668,411	700,770	233,590	233,590	233,590	*
Jul-22	638,097	555,748	185,249	185,249	185,249	*
Aug-22	577,992	280,279	55,330	81,647	143,302	**
Sep-22	631,697	677,002	239,176	217,343	220,483	
Oct-22	1,003,602	1,496,092	512,714	497,365	486,013	
Nov-22	1,395,914	1,515,960	520,077	499,774	496,109	
Dec-22	1,278,858	1,462,265	467,266	514,480	480,519	
Jan-23	1,332,437	1,150,057	407,479	370,851	371,727	
Feb-23	1,157,019	1,499,564	513,873	511,795	473,896	
Mar-23	1,242,761	1,403,979	477,517	451,995	474,467	****
Apr-23	1,447,248	1,194,254	398,085	398,085	398,085	*
Production 2023 (ytd) (kWh)	5,179,464	5,247,854	1,796,954	1,732,726	1,718,175	
Total Production (kWh) (LTM)	12,384,999	13,099,536	4,398,211	4,350,029	4,351,295	
Capacity Factor (LTM)	33.23%					

B. Site Energy Production Graph

April-2023



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
May-2023	10.5 Year Maintenance	~8	WTG A
May-2023	10.5 Year Maintenance	~8	WTG B
May-2023	10.5 Year Maintenance	~8	WTG C

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
------	-------	-------------------	----------------	---------

F. Turbine Availability & Downtime***

Availability	This Month	Year To Date
WTG A	100.00%	100.00%
WTG B	100.00%	99.09%
WTG C	100.00%	98.21%
Avg	100.00%	99.10%

Downtime (hr)	This Month	Year To Date
WTG A	0	61.51
WTG B	0	48.38
WTG C	0	71.36
Total	0	181.25

G. Wind Speed & Capacity Factor

Wind Speed (mph)	This Month	2022 Annual
WTG A		13.73
WTG B		13.37
WTG C		14.38
Estimated	16.62	13.39

Capacity Factor (%)	This Month	2022 Annual
WTG A	36.86%	43.17%
WTG B	36.86%	41.19%
WTG C	36.86%	41.20%
Low Estimate	42.22%	28.72%

H. Report Notes and Comments

*Production read from the meter due to SCADA communication issues.

**August 2022 production is lower than actual due to SCADA communication issues.

***Due to expiration of the OEM warranty, turbine availability and downtime reporting will no longer include warrantied availability. Downtime will be categorized appropriately.

****March 2023 WTG Energy Production contains estimates due to a SCADA error. 3/30/2023 and 3/31/2023 are missing data for all 3 Turbines.