


A. Site Energy Production Summary

	Energy Production (kWh)			
	Site		By Turbine	
	P50 (Expected Production)	Actual Production	W1	W2
Apr-22	951,000	795,380	402,642	392,738
May-22	601,000	614,219	307,353	306,866
Jun-22	425,000	413,887	205,685	208,202
Jul-22	390,000	405,644	204,608	201,036
Aug-22	399,000	316,041	159,653	156,388
Sep-22	337,000	370,915	189,397	181,518
Oct-22	637,000	822,082	414,170	407,912
Nov-22	834,000	952,177	479,422	472,755
Dec-22	1,015,000	920,397	460,812	459,585
Jan-23	875,000	703,088	359,790	343,298
Feb-23	917,000	890,580	449,499	441,081
Mar-23	802,000	918,289	462,488	455,801
Apr-23	951,000	686,249	342,823	343,426
Production 2023 (ytd) (kWh)	3,545,000	3,198,206	1,614,600	1,583,606
Total Production (kWh) (LTM)	8,183,000	8,013,568	4,035,700	3,977,868
Capacity Factor (LTM)	30.49%			

B. Site Energy Production Graph

April-2023



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
May-2023	Goldwind 7.5 Year Maintenance	~8	W1
May-2023	Goldwind 7.5 Year Maintenance	~8	W2

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
4/1/2023	Weather Shutdown	Unplanned	9.47	W1
4/1/2023	Weather Shutdown	Unplanned	9.74	W2
4/26/2023	Customer Shutdown	Unplanned	4.82	W1

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
W1	100.00%	99.97%
W2	100.00%	99.94%
Avg	100.00%	99.96%

Downtime (hr)	This Month	Year To Date
W1	17.21	42.36
W2	14.94	40.27
Total	32.15	82.63

G. Billed Data

Meter Reading (Date/Time)	4/29/2023 12:00 AM
Meter To Date Produced	56,867,654 kWh
Meter To Date Consumed	108,787 kWh
Last Reading Produced	56,128,291 kWh
Last Reading Consumed	107,782 kWh
Billed kWh	738,358 kWh
Next Meter Reading	5/29/2023 12:00 AM

H. Report Notes and Comments