


A. Site Energy Production Summary

	Energy Production (kWh)			
	Site		By Turbine	
	P50 (Expected Production)	Actual Production	V1	V2
Apr-22	722,000	794,963	403,811	391,152
May-22	564,000	648,467	329,704	318,763
Jun-22	422,000	414,874	202,214	212,660
Jul-22	351,000	385,489	190,281	195,208
Aug-22	303,000	297,191	147,920	149,271
Sep-22	431,000	383,178	188,508	194,670
Oct-22	674,000	770,712	390,964	379,748
Nov-22	796,000	889,743	458,319	431,424
Dec-22	820,000	853,742	430,989	422,753
Jan-23	931,000	675,941	335,912	340,029
Feb-23	737,000	890,155	447,488	442,667
Mar-23	777,000	897,476	445,429	452,047
Apr-23	722,000	669,323	334,035	335,288
Production 2023 (ytd) (kWh)	3,167,000	3,132,895	1,562,864	1,570,031
Total Production (LTM) (kWh)	7,528,000	7,776,291	3,901,763	3,874,528
Capacity Factor (LTM)	29.59%			

B. Site Energy Production Graph



Monthly Report

April-2023

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	1

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
May-2023	Goldwind 4.5 Year Maintenance	~8	V1
May-2023	Goldwind 4.5 Year Maintenance	~8	V2

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
------	-------	-------------------	----------------	---------

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
V1	100.00%	100.00%
V2	100.00%	99.93%
Avg	100.00%	99.96%

Downtime (hr)	This Month	Year To Date
V1	6.60	34.23
V2	6.60	35.74
Total	13.20	69.97

G. Billed Data

Meter Reading (Date/Time)	5/1/2023 12:00 AM
Meter To Date Produced	34,396,021 kWh
Meter To Date Consumed	83,549 kWh
Last Reading Produced	33,748,618 kWh
Last Reading Consumed	81,963 kWh
Billed kWh	645,817 kWh
Next Meter Reading	6/1/2023 12:00 AM

H. Report Notes and Comments