


A. Site Energy Production Summary

	Energy Production (kWh)	
	Site	
	P50 (Expected Production)	Actual Production
May-22	318,000	366,781
Jun-22	222,000	230,391
Jul-22	201,000	220,456
Aug-22	211,000	178,498
Sep-22	182,000	210,137
Oct-22	341,000	453,178
Nov-22	445,000	483,244
Dec-22	537,000	425,026
Jan-23	455,000	385,892
Feb-23	478,000	479,787
Mar-23	422,000	431,283
Apr-23	499,000	336,641
May-23	318,000	281,525
Production 2023 (ytd) (kWh)	2,172,000	1,915,128
Total Production (LTM) (kWh)	4,311,000	4,116,058
Capacity Factor (LTM)	31.32%	

B. Site Energy Production Graph

May-2023



Monthly Report
May-2023

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
October-2023	Goldwind 5.5 Year Maintenance	~15	W1

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
5/24/2023	Turbine Fault	Unplanned	5.02	W1

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
W1	99.01%	99.34%
Downtime (hr)	This Month	Year To Date
W1	8.74	145.61

G. Billed Data

Meter Reading (Date/Time)	6/1/2023 12:00 AM
Meter To Date Produced	21,532,372 kWh
Meter To Date Consumed	90,773 kWh
Last Reading Produced	21,255,992 kWh
Last Reading Consumed	89,347 kWh
Billed kWh	274,954 kWh
Next Meter Reading	7/1/2023 12:00 AM

H. Report Notes and Comments