


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	L1	L2	L3
May-22	1,052,000	1,077,013	373,367	344,704	358,942
Jun-22	751,000	648,158	241,123	200,574	206,461
Jul-22	609,000	601,624	214,570	198,293	188,761
Aug-22	534,000	495,062	174,285	161,531	159,246
Sep-22	736,000	590,681	207,671	205,644	177,366
Oct-22	1,131,000	1,314,977	441,919	437,021	436,037
Nov-22	1,281,000	1,358,321	450,327	452,535	455,459
Dec-22	1,263,000	1,435,227	471,526	479,772	483,929
Jan-23	1,433,000	1,025,974	346,845	343,212	335,917
Feb-23	1,213,000	1,437,228	466,816	492,962	477,450
Mar-23	1,339,000	1,477,116	494,371	495,751	486,994
Apr-23	1,327,000	1,072,001	362,508	361,635	347,858
May-23	1,052,000	809,644	273,086	279,357	257,201
Production 2022 (ytd) (kWh)	6,364,000	5,821,963	1,943,626	1,972,917	1,905,420
Total Production (LTM) (kWh)	12,669,000	12,266,013	4,145,047	4,108,287	4,012,679
Capacity Factor (LTM)	31.12%				

B. Site Energy Production Graph

May-2023



Monthly Report
May-2023

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
October-2023	Goldwind 3 Year Maintenance	~15	L1
October-2023	Goldwind 3 Year Maintenance	~15	L2
October-2023	Goldwind 3 Year Maintenance	~15	L3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
------	-------	-------------------	----------------	---------

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
L1	100.00%	98.64%
L2	100.00%	100.00%
L3	100.00%	99.62%
Avg	100.00%	99.42%

Downtime (hr)	This Month	Year To Date
L1	0.11	98.50
L2		56.34
L3		69.92
Total	0.11	224.76

G. Billed Data

Meter Reading (Date/Time)	5/26/2023 12:00 AM
Meter To Date Produced	34,366,073 kWh
Meter To Date Consumed	100,444 kWh
Last Reading Produced	33,537,596 kWh
Last Reading Consumed	97,505 kWh
Billed kWh	825,538 kWh
Next Meter Reading	6/27/2023 12:00 AM

H. Report Notes and Comments