

A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	Expected Production	Actual Production	WTG 1	WTG 2	WTG 3
Jun-22	649,158	765,507	272,227	239,819	253,461
Jul-22	618,687	617,049	214,843	198,590	203,616
Aug-22	559,508	531,092	179,942	168,860	182,290
Sep-22	603,085	395,973	133,364	128,586	134,023
Oct-22	967,926	1,373,420	466,421	429,871	477,128
Nov-22	1,362,692	1,568,093	527,267	521,360	519,466
Dec-22	1,254,397	1,487,190	491,635	498,005	497,550
Jan-23	1,290,968	1,253,314	423,857	413,023	416,434
Feb-23	1,170,349	1,453,948	522,598	439,412	491,938
Mar-23	1,227,217	1,298,079	501,593	304,805	491,681
Apr-23	1,438,497	1,155,788	408,089	343,589	404,110
May-23	980,450	753,863	267,560	252,701	233,602
Jun-23	649,158	683,362	267,560	252,701	233,602
Production 2023 (ytd) (kWh)	6,756,639	6,598,354	2,355,286	1,981,987	2,261,081
Total Production (LTM) (kWh)	12,122,935	12,571,171	4,404,729	3,951,503	4,285,440
Capacity Factor (LTM)	31.89%				

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events


Date	Event	Duration (hr)	Turbine
November-2023	11 Year Maintenance	~15	WTG 1
November-2023	11 Year Maintenance	~15	WTG 2
November-2023	11 Year Maintenance	~15	WTG 3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
------	-------	-------------------	----------------	---------

B. Site Energy Production Graph

June-2023



F. Turbine Availability & Downtime**

Availability	This Month	Year To Date
WTG 1	100.00%	100.00%
WTG 2	100.00%	100.00%
WTG 3	100.00%	99.99%
Avg	100.00%	100.00%

Downtime (hr)	This Month	Year To Date
WTG 1	3.09	114.63
WTG 2	3.09	578.15
WTG 3	3.06	88.38
Total	9.24	781.16

G. Wind Speed & Capacity Factor

Wind Speed (mph)	This Month	2022 Annual
WTG 1	4.94	14.41
WTG 2	4.90	14.29
WTG 3	4.97	14.49
Estimated	11.44	13.39

Capacity Factor (%)	This Month	2022 Annual
WTG 1	25.21%	44.69%
WTG 2	22.21%	35.72%
WTG 3	23.47%	43.21%
Low Estimate	17.87%	28.72%

H. Report Notes and Comments

* September 2022 production is lower than actual due to SCADA communication issues.

**Due to expiration of the OEM warranty, turbine availability and downtime reporting will no longer include warranted availability. Downtime will be categorized appropriately. One Energy will update future reports to reflect this change.