


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	WG1	WG2	WG3
Jun-22	714,000	591,297	204,680	194,977	191,640
Jul-22	566,000	501,161	169,673	169,616	161,872
Aug-22	514,000	462,848	160,121	151,764	150,963
Sep-22	716,000	611,606	217,120	197,200	197,286
Oct-22	1,051,000	1,275,567	446,816	420,408	408,343
Nov-22	1,224,000	1,260,789	450,647	410,211	399,931
Dec-22	1,217,000	1,186,817	407,671	389,062	390,084
Jan-23	1,343,000	1,022,726	364,829	333,353	324,544
Feb-23	1,133,000	1,357,316	469,593	443,298	444,425
Mar-23	1,312,000	1,397,327	483,104	451,227	462,996
Apr-23	1,272,000	971,079	347,951	314,716	308,412
May-23	974,000	666,913	244,432	206,831	215,650
Jun-23	714,000	586,809	200,667	193,800	192,342
Production 2023 (ytd) (kWh)	6,748,000	6,002,170	2,110,576	1,943,225	1,948,369
Total Production (kWh) (LTM)	12,036,000	11,300,958	3,962,624	3,681,486	3,656,848
Capacity Factor (LTM)	28.67%				

B. Site Energy Production Graph

June-2023



Monthly Report

June-2023

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
November-2023	Goldwind 5 Year Maintenance	~15	WG 1
November-2023	Goldwind 5 Year Maintenance	~15	WG 2
November-2023	Goldwind 5 Year Maintenance	~15	WG 3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
6/20/2023-6/21/2023	Turbine Fault	Unplanned	18.31	WG 3

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
WG1	100.00%	99.99%
WG2	100.00%	99.39%
WG3	97.46%	98.69%
Avg	99.15%	99.36%

Downtime (hr)	This Month	Year To Date
WG1	0.18	48.97
WG2	0.18	71.96
WG3	18.42	88.96
Total	18.78	209.89

G. Billed Data

Meter Reading (Date/Time)	6/29/2023 12:00 AM
Meter To Date Produced	51,553,755 kWh
Meter To Date Consumed	181,219 kWh
Last Reading Produced	50,975,367 kWh
Last Reading Consumed	177,083 kWh
Billed kWh	574,252 kWh
Next Meter Reading	7/29/2023 12:00 AM

H. Report Notes and Comments