


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	L1	L2	L3
Jul-22	609,000	601,624	214,570	198,293	188,761
Aug-22	534,000	495,062	174,285	161,531	159,246
Sep-22	736,000	590,681	207,671	205,644	177,366
Oct-22	1,131,000	1,314,977	441,919	437,021	436,037
Nov-22	1,281,000	1,358,321	450,327	452,535	455,459
Dec-22	1,263,000	1,435,227	471,526	479,772	483,929
Jan-23	1,433,000	1,025,974	346,845	343,212	335,917
Feb-23	1,213,000	1,437,228	466,816	492,962	477,450
Mar-23	1,339,000	1,477,116	494,371	495,751	486,994
Apr-23	1,327,000	1,072,001	362,508	361,635	347,858
May-23	1,052,000	809,644	273,086	279,357	257,201
Jun-23	751,000	649,782	224,391	226,181	199,210
Jul-23	609,000	360,370	124,670	123,847	111,853
Production 2022 (ytd) (kWh)	7,724,000	6,832,115	2,292,687	2,322,945	2,216,483
Total Production (LTM) (kWh)	12,669,000	12,026,383	4,038,415	4,059,448	3,928,520
Capacity Factor (LTM)	30.51%				

B. Site Energy Production Graph

July-2023



Monthly Report

July-2023

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
October-2023	Goldwind 3 Year Maintenance	~15	L1
October-2023	Goldwind 3 Year Maintenance	~15	L2
October-2023	Goldwind 3 Year Maintenance	~15	L3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
7/22/2023-7/24/2023	Customer Shutdown	Unplanned	43.55	L1
7/22/2023-7/24/2023	Customer Shutdown	Unplanned	43.55	L2
7/22/2023-7/24/2023	Customer Shutdown	Unplanned	43.55	L3

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
L1	100.00%	99.03%
L2	100.00%	100.00%
L3	100.00%	99.73%
Avg	100.00%	99.59%

Downtime (hr)	This Month	Year To Date
L1	47.91	150.13
L2	47.91	107.97
L3	47.91	121.55
Total	143.73	379.65

G. Billed Data

Meter Reading (Date/Time)	7/27/2023 12:00 AM
Meter To Date Produced	35,421,061 kWh
Meter To Date Consumed	110,940 kWh
Last Reading Produced	35,047,606 kWh
Last Reading Consumed	104,340 kWh
Billed kWh	366,855 kWh
Next Meter Reading	8/25/2023 12:00 AM

H. Report Notes and Comments