

A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	Expected Production	Actual Production	WTG 1	WTG 2	WTG 3
Aug-22	559,508	531,092	179,942	168,860	182,290
Sep-22	603,085	395,973	133,364	128,586	134,023
Oct-22	967,926	1,373,420	466,421	429,871	477,128
Nov-22	1,362,692	1,568,093	527,267	521,360	519,466
Dec-22	1,254,397	1,487,190	491,635	498,005	497,550
Jan-23	1,290,968	1,253,314	423,857	413,023	416,434
Feb-23	1,170,349	1,453,948	522,598	439,412	491,938
Mar-23	1,227,217	1,298,079	501,593	304,805	491,681
Apr-23	1,438,497	1,155,788	408,089	343,589	404,110
May-23	980,450	753,863	252,701	233,602	267,560
Jun-23	649,158	683,362	231,589	228,457	223,316
Jul-23	618,687	440,827	132,214	148,791	159,822
Aug-23	559,508	555,831	128,322	211,051	216,458
Production 2023 (ytd) (kWh)	7,934,835	7,595,012	2,600,963	2,322,730	2,671,319
Total Production (LTM) (kWh)	12,122,935	12,419,688	4,219,650	3,900,552	4,299,486
Capacity Factor (LTM)	31.51%				

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events


Date	Event	Duration (hr)	Turbine
November-2023	11 Year Maintenance	~15	WTG 1
November-2023	11 Year Maintenance	~15	WTG 2
November-2023	11 Year Maintenance	~15	WTG 3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
8/1/2023-8/15/2023	Turbine Fault	Unplanned	316.03	WTG 1

B. Site Energy Production Graph

August-2023



F. Turbine Availability & Downtime**

Availability	This Month	Year To Date
WTG 1	100.00%	100.00%
WTG 2	100.00%	100.00%
WTG 3	100.00%	99.99%
Avg	100.00%	100.00%

Downtime (hr)	This Month	Year To Date
WTG 1	316.03	554.69
WTG 2		579.45
WTG 3		89.67
Total	316.03	1223.81

G. Wind Speed & Capacity Factor

Wind Speed (mph)	This Month	2022 Annual
WTG 1	4.94	14.41
WTG 2	4.90	14.29
WTG 3	4.97	14.49
Estimated	11.09	13.39

Capacity Factor (%)	This Month	2022 Annual
WTG 1	11.50%	44.69%
WTG 2	18.91%	35.72%
WTG 3	19.40%	43.21%
Low Estimate	14.90%	28.72%

H. Report Notes and Comments

* September 2022 production is lower than actual due to SCADA communication issues.

**Due to expiration of the OEM warranty, turbine availability and downtime reporting will no longer include warranted availability. Downtime will be categorized appropriately. One Energy will update future reports to reflect this change.