


A. Site Energy Production Summary

	Energy Production (kWh)			
	Site		By Turbine	
	P50 (Expected Production)	Actual Production	W1	W2
Aug-22	399,000	316,041	159,653	156,388
Sep-22	337,000	370,915	189,397	181,518
Oct-22	637,000	822,082	414,170	407,912
Nov-22	834,000	952,177	479,422	472,755
Dec-22	1,015,000	920,397	460,812	459,585
Jan-23	875,000	703,088	359,790	343,298
Feb-23	917,000	890,580	449,499	441,081
Mar-23	802,000	918,289	462,488	455,801
Apr-23	951,000	686,249	342,823	343,426
May-23	601,000	541,021	268,754	272,267
Jun-23	425,000	413,801	210,347	203,454
Jul-23	390,000	267,109	135,436	131,673
Aug-23	390,000	366,119	185,571	180,548
Production 2023 (ytd) (kWh)	4,961,000	4,786,256	2,414,708	2,371,548
Total Production (kWh) (LTM)	8,174,000	7,851,827	3,958,509	3,893,318
Capacity Factor (LTM)	29.88%			

B. Site Energy Production Graph

August-2023



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
November-2023	Goldwind 8 Year Maintenance	~15	W1
November-2023	Goldwind 8 Year Maintenance	~15	W2

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
------	-------	-------------------	----------------	---------

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
W1	100.00%	99.98%
W2	100.00%	99.92%
Avg	100.00%	99.95%

Downtime (hr)	This Month	Year To Date
W1	8.15	66.78
W2	5.99	62.85
Total	14.14	129.63

G. Billed Data

Meter Reading (Date/Time)	8/29/2023 12:00 AM
Meter To Date Produced	58,462,631 kWh
Meter To Date Consumed	114,943 kWh
Last Reading Produced	58,107,164 kWh
Last Reading Consumed	113,418 kWh
Billed kWh	353,942 kWh
Next Meter Reading	9/29/2023 12:00 AM

H. Report Notes and Comments