


A. Site Energy Production Summary

	Energy Production (kWh)			
	Site		By Turbine	
	P50 (Expected Production)	Actual Production	V1	V2
Aug-22	303,000	297,191	147,920	149,271
Sep-22	431,000	383,178	188,508	194,670
Oct-22	674,000	770,712	390,964	379,748
Nov-22	796,000	889,743	458,319	431,424
Dec-22	820,000	853,742	430,989	422,753
Jan-23	931,000	675,941	335,912	340,029
Feb-23	737,000	890,155	447,488	442,667
Mar-23	777,000	897,476	445,429	452,047
Apr-23	722,000	669,323	334,035	335,288
May-23	564,000	550,907	281,748	269,159
Jun-23	422,000	414,035	207,507	206,528
Jul-23	351,000	239,451	127,232	112,219
Aug-23	303,000	352,751	170,780	181,971
Production 2023 (ytd) (kWh)	4,807,000	4,690,039	2,350,131	2,339,908
Total Production (LTM) (kWh)	7,528,000	7,587,414	3,818,911	3,768,503
Capacity Factor (LTM)	28.87%			

B. Site Energy Production Graph

August-2023



Monthly Report

August-2023

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	1

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
November-2023	Goldwind 5 Year Maintenance	~15	V1
November-2023	Goldwind 5 Year Maintenance	~15	V2

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
8/4/2023	Turbine Fault	Unplanned	6.62	V2
8/9/2023	Turbine Fault	Unplanned	5.00	V1

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
V1	99.27%	99.83%
V2	98.91%	98.09%
Avg	99.09%	98.96%

Downtime (hr)	This Month	Year To Date
V1	6.69	53.37
V2	9.37	159.14
Total	16.06	212.51

G. Billed Data

Meter Reading (Date/Time)	9/1/2023 12:00 AM
Meter To Date Produced	35,895,817 kWh
Meter To Date Consumed	92,499 kWh
Last Reading Produced	35,556,910 kWh
Last Reading Consumed	90,286 kWh
Billed kWh	336,694 kWh
Next Meter Reading	10/1/2023 12:00 AM

H. Report Notes and Comments