


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	W1	W2	W3
Aug-22	449,000	347,940	115,055	112,651	120,234
Sep-22	610,000	457,923	158,634	147,583	151,706
Oct-22	990,000	1,055,135	352,633	347,490	355,012
Nov-22	1,123,000	1,082,893	325,653	379,517	377,723
Dec-22	1,153,000	1,101,489	370,953	359,782	370,754
Jan-23	1,306,000	944,567	321,372	299,859	323,336
Feb-23	1,137,000	1,207,889	412,812	394,263	400,814
Mar-23	1,134,000	1,210,201	411,439	394,303	404,459
Apr-23	1,176,000	806,391	278,072	255,852	272,467
May-23	927,000	720,365	248,247	228,868	243,250
Jun-23	634,000	500,917	167,545	157,935	175,437
Jul-23	527,000	311,849	99,568	102,035	110,246
Aug-23	449,000	398,914	133,449	128,288	137,177
Production 2023 (ytd) (kWh)	7,290,000	6,101,093	2,072,504	1,961,403	2,067,186
Total Production (kWh) (LTM)	11,166,000	9,798,533	3,280,377	3,195,775	3,322,381
Capacity Factor (LTM)	24.86%				

B. Site Energy Production Graph

August-2023



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	1

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
November-2023	Goldwind 6 Year Maintenance	~15	W1
November-2023	Goldwind 6 Year Maintenance	~15	W2
November-2023	Goldwind 6 Year Maintenance	~15	W3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
------	-------	-------------------	----------------	---------

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
W1	100.00%	97.66%
W2	100.00%	99.95%
W3	100.00%	99.67%
Avg	100.00%	99.09%

Downtime (hr)	This Month	Year To Date
W1	6.06	244.99
W2	6.06	105.08
W3	6.06	124.72
Total	18.18	474.79

G. Billed Data

Meter Reading (Date/Time)	8/21/2023 12:00 AM
Meter To Date Produced	53,629,155 kWh
Meter To Date Consumed	164,006 kWh
Last Reading Produced	53,273,143 kWh
Last Reading Consumed	159,569 kWh
Billed kWh	351,575 kWh
Next Meter Reading	9/21/2023 12:00 AM

H. Report Notes and Comments