




A. Site Energy Production Summary

	Energy Production (kWh)					
	Site		By Turbine			
	Expected Production	Actual Production	WTG A	WTG B	WTG C	
Sep-22	631,697	677,002	239,176	217,343	220,483	
Oct-22	1,003,602	1,496,092	512,714	497,365	486,013	
Nov-22	1,395,914	1,515,960	520,077	499,774	496,109	
Dec-22	1,278,858	1,462,265	467,266	514,480	480,519	
Jan-23	1,332,437	1,150,057	407,479	370,851	371,727	
Feb-23	1,157,019	1,499,564	513,873	511,795	473,896	
Mar-23	1,242,761	1,403,979	477,517	451,995	474,467	***
Apr-23	1,447,248	1,194,254	398,085	398,085	398,085	*
May-23	1,010,966	887,683	300,440	287,583	299,660	****
Jun-23	668,411	610,504	240,557	117,217	252,730	
Jul-23	638,097	331,312	124,906	135,529	70,877	
Aug-23	577,992	642,748	209,098	212,029	221,621	
Sep-23	631,697	463,267	154,792	153,657	154,818	
Production 2023 (ytd) (kWh)	8,706,626	8,183,368	2,826,747	2,638,741	2,717,881	
Total Production (kWh) (LTM)	12,385,000	12,657,685	4,326,804	4,150,360	4,180,522	
Capacity Factor (LTM)	32.11%					

B. Site Energy Production Graph

September-2023



Monthly Report
September-2023

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
December-2023	11 Year Maintenance	~15	WTG A
December-2023	11 Year Maintenance	~15	WTG B
December-2023	11 Year Maintenance	~15	WTG C

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
------	-------	-------------------	----------------	---------

F. Turbine Availability & Downtime**

Availability	This Month	Year To Date
WTG A	100.00%	100.00%
WTG B	100.00%	99.60%
WTG C	100.00%	99.20%
Avg	100.00%	99.60%

Downtime (hr)	This Month	Year To Date
WTG A	0	336.24
WTG B	0	458.11
WTG C	0	412.67
Total	0	1207.02

G. Wind Speed & Capacity Factor

Wind Speed (mph)	This Month	2022 Annual
WTG A	8.71	11.13
WTG B	8.63	10.82
WTG C	9.32	11.76
Estimated	11.09	13.39

Capacity Factor (%)	This Month	2022 Annual
WTG A	14.33%	27.76%
WTG B	14.23%	25.61%
WTG C	14.34%	26.63%
Low Estimate	18.42%	28.72%

H. Report Notes and Comments

*Production read from the meter due to SCADA communication issues.

**Due to expiration of the OEM warranty, turbine availability and downtime reporting will no longer include warrantied availability. Downtime will be categorized appropriately.

***March 2023 WTG Energy Production contains estimates due to a SCADA error. 3/30/2023 and 3/31/2023 are missing data for all 3 Turbines.

****May 2023 - 5/7/2023 and 5/8/2023 Production is from the meter due to a SCADA server error.