


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	L1	L2	L3
Sep-22	736,000	590,681	207,671	205,644	177,366
Oct-22	1,131,000	1,314,977	441,919	437,021	436,037
Nov-22	1,281,000	1,358,321	450,327	452,535	455,459
Dec-22	1,263,000	1,435,227	471,526	479,772	483,929
Jan-23	1,433,000	1,025,974	346,845	343,212	335,917
Feb-23	1,213,000	1,437,228	466,816	492,962	477,450
Mar-23	1,339,000	1,477,116	494,371	495,751	486,994
Apr-23	1,327,000	1,072,001	362,508	361,635	347,858
May-23	1,052,000	809,644	273,086	279,357	257,201
Jun-23	751,000	649,782	224,391	226,181	199,210
Jul-23	609,000	360,370	124,670	123,847	111,853
Aug-23	534,000	594,879	204,225	207,630	183,024
Sep-23	736,000	400,037	139,966	142,124	117,947
Production 2023 (ytd) (kWh)	8,994,000	7,827,031	2,636,878	2,672,699	2,517,454
Total Production (LTM) (kWh)	12,669,000	11,935,556	4,000,650	4,042,027	3,892,879
Capacity Factor (LTM)	30.28%				

B. Site Energy Production GraphSeptember-2023



Monthly ReportSeptember-2023

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration	Turbine
		(hr)	
March-2024	Goldwind 3.5 Year Maintenance	~8	L1
March-2024	Goldwind 3.5 Year Maintenance	~8	L2
March-2024	Goldwind 3.5 Year Maintenance	~8	L3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
9/12/2023	Goldwind 3 Year Maintenance	Planned	2.87	L1
9/13/2023	Goldwind 3 Year Maintenance	Planned	2.68	L2
9/14/2023	Goldwind 3 Year Maintenance	Planned	3.1	L3

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
L1	100.00%	99.25%
L2	100.00%	100.00%
L3	99.89%	99.78%
Avg	99.96%	99.68%

Downtime (hr)	This Month	Year To Date
L1	2.87	153.00
L2	2.68	110.65
L3	3.92	125.47
Total	9.47	389.12

G. Billed Data

Meter Reading (Date/Time)	9/26/2023 12:00 AM
Meter To Date Produced	36,406,438 kWh
Meter To Date Consumed	120,399 kWh
Last Reading Produced	35,975,974 kWh
Last Reading Consumed	115,507 kWh
Billed kWh	425,572 kWh
Next Meter Reading	10/25/2023 12:00 AM

H. Report Notes and Comments