


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	Expected Production	Actual Production	WTG 1	WTG 2	WTG 3
Oct-22	967,926	1,373,420	466,421	429,871	477,128
Nov-22	1,362,692	1,568,093	527,267	521,360	519,466
Dec-22	1,254,397	1,487,190	491,635	498,005	497,550
Jan-23	1,290,968	1,253,314	423,857	413,023	416,434
Feb-23	1,170,349	1,453,948	522,598	439,412	491,938
Mar-23	1,227,217	1,298,079	501,593	304,805	491,681
Apr-23	1,438,497	1,155,788	408,089	343,589	404,110
May-23	980,450	753,863	252,701	233,602	267,560
Jun-23	649,158	683,362	231,589	228,457	223,316
Jul-23	618,687	440,827	132,214	148,791	159,822
Aug-23	559,508	555,831	128,322	211,051	216,458
Sep-23	603,085	353,794	138,579	132,576	82,639
Oct-23	967,926	1,001,240	338,432	337,485	325,323
Production 2023 (ytd) (kWh)	9,505,846	8,950,046	3,077,974	2,792,791	3,079,281
Total Production (LTM) (kWh)	12,122,935	12,005,329	4,096,876	3,812,156	4,096,297
Capacity Factor (LTM)	30.45%				

B. Site Energy Production Graph

October-2023



Monthly Report

October-2023

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
May-2023	11.5 Year Maintenance	~8	WTG 1
May-2023	11.5 Year Maintenance	~8	WTG 2
May-2023	11.5 Year Maintenance	~8	WTG 3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
10/1/2023	Blade Repair	Unplanned	12.25	WTG 1
10/11/2023	Grid Fault	Unplanned	8.52	WTG 1
10/11/2023	Grid Fault	Unplanned	8.55	WTG 2
10/11/2023	Grid Fault	Unplanned	8.57	WTG 3
10/16/2023	11 Year Maintenance	Planned	6.6	WTG 2
10/17/2023	11 Year Maintenance	Planned	1.72	WTG 2
10/17/2023	11 Year Maintenance	Planned	3.75	WTG 1
10/17/2023	11 Year Maintenance	Planned	5.13	WTG 3
10/18/2023	11 Year Maintenance	Planned	3.28	WTG 1
10/30/2023-10/31/2023	Grid Fault	Unplanned	33.22	WTG 1, WTG 2, WTG 3

F. Turbine Availability & Downtime*

Availability	This Month	Year To Date
WTG 1	100.00%	100.00%
WTG 2	100.00%	100.00%
WTG 3	100.00%	99.99%
Avg	100.00%	100.00%

Downtime (hr)	This Month	Year To Date
WTG 1	61.85	750.21
WTG 2	248.57	883.05
WTG 3	47.76	319.91
Total	164.54	1953.17

G. Wind Speed & Capacity Factor

Wind Speed (mph)	This Month	2022 Annual
WTG 1	4.94	14.41
WTG 2	4.90	14.29
WTG 3	4.97	14.49
Estimated	13.89	13.39

Capacity Factor (%)	This Month	2022 Annual
WTG 1	30.33%	44.69%
WTG 2	30.24%	35.72%
WTG 3	29.15%	43.21%
Low Estimate	25.82%	28.72%

H. Report Notes and Comments

*Due to expiration of the OEM warranty, turbine availability and downtime reporting will no longer include warranted availability. Downtime will be categorized appropriately. One Energy will update future reports to reflect this change.