




A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	Expected Production	Actual Production	WTG A	WTG B	WTG C
Oct-22	1,003,602	1,496,092	512,714	497,365	486,013
Nov-22	1,395,914	1,515,960	520,077	499,774	496,109
Dec-22	1,278,858	1,462,265	467,266	514,480	480,519
Jan-23	1,332,437	1,150,057	407,479	370,851	371,727
Feb-23	1,157,019	1,499,564	513,873	511,795	473,896
Mar-23	1,242,761	1,403,979	477,517	451,995	474,467
Apr-23	1,447,248	1,194,254	398,085	398,085	398,085
May-23	1,010,966	887,683	300,440	287,583	299,660
Jun-23	668,411	610,504	240,557	117,217	252,730
Jul-23	638,097	331,312	124,906	135,529	70,877
Aug-23	577,992	642,748	209,098	212,029	221,621
Sep-23	631,697	463,267	154,792	153,657	154,818
Oct-23	1,003,602	1,091,106	381,773	348,712	360,621
Production 2023 (ytd) (kWh)	9,710,228	9,274,474	3,208,520	2,987,453	3,078,502
Total Production (LTM) (kWh)	12,385,000	12,252,699	4,195,863	4,001,707	4,055,130
Capacity Factor (LTM)	31.08%				

B. Site Energy Production Graph

October-2023



Monthly Report
October-2023

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
December-2023	11 Year Maintenance	~15	WTG A
December-2023	11 Year Maintenance	~15	WTG B
December-2023	11 Year Maintenance	~15	WTG C

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
10/8/2023	Grid Fault	Unplanned	6.7	WTG A
10/8/2023	Grid Fault	Unplanned	6.01	WTG B
10/8/2023	Grid Fault	Unplanned	7.02	WTG C
10/9/2023	Turbine Fault	Unplanned	4.92	WTG B
10/21/2023-10/22/2023	Turbine Fault	Unplanned	20.55	WTG B

F. Turbine Availability & Downtime**

Availability	This Month	Year To Date
WTG A	100.00%	100.00%
WTG B	100.00%	99.64%
WTG C	100.00%	99.28%
Avg	100.00%	99.64%

Downtime (hr)	This Month	Year To Date
WTG A	12.97	349.21
WTG B	34.09	492.20
WTG C	10.32	422.99
Total	57.38	1264.40

G. Wind Speed & Capacity Factor

Wind Speed (mph)	This Month	2022 Annual
WTG A	12.53	11.30
WTG B	11.86	10.94
WTG C	12.89	11.89
Estimated	13.89	13.39

Capacity Factor (%)	This Month	2022 Annual
WTG A	34.21%	28.49%
WTG B	31.25%	26.25%
WTG C	32.31%	27.27%
Low Estimate	25.82%	28.72%

H. Report Notes and Comments

*Production read from the meter due to SCADA communication issues.

**Due to expiration of the OEM warranty, turbine availability and downtime reporting will no longer include warrantied availability. Downtime will be categorized appropriately.

***March 2023 WTG Energy Production contains estimates due to a SCADA error. 3/30/2023 and 3/31/2023 are missing data for all 3 Turbines.

****May 2023 - 5/7/2023 and 5/8/2023 Production is from the meter due to a SCADA server error.