



HARPSTER WIND PROJECT


Harpster, OH

A. Site Energy Production Summary

	Energy Production (kWh)	
	Site	
	P50 (Expected Production)	Actual Production
Dec-22	403,000	314,804
Jan-23	460,000	327,622
Feb-23	372,000	401,881
Mar-23	417,000	361,885
Apr-23	399,000	272,556
May-23	311,000	214,744
Jun-23	228,000	169,424
Jul-23	179,000	116,572
Aug-23	157,000	139,977
Sep-23	224,000	93,945
Oct-23	338,000	245,587
Nov-23	402,000	324,788
Dec-23	403,000	257,014
Production 2023 (ytd) (kWh)	3,890,000	2,925,995
Total Production (LTM) (kWh)	3,890,000	2,925,995
Capacity Factor (LTM)	22.27%	

B. Site Energy Production Graph

December-2023



Monthly Report

December-2023



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
April-2024	Goldwind 8 Year Maintenance	~15	H1

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
12/9/2023	Grid Fault	Unplanned	11.38	H1
12/10/2023-12/11/2023	Grid Fault	Unplanned	13.41	H1
12/18/2023-12/19/2023	Turbine Fault	Unplanned	19.18	H1

F. Turbine Availability & Downtime

Availability	This Month	Year To Date
H1	97.42%	99.25%
Downtime (hr)	This Month	Year To Date
H1	44.12	315.23

G. Billed Data

Meter Reading (Date/Time)	12/28/2023 12:00 AM
Meter To Date Produced	25,670,737 kWh
Meter To Date Consumed	84,649 kWh
Last Reading Produced	25,332,346 kWh
Last Reading Consumed	83,969 kWh
Billed kWh	337,711 kWh
Next Meter Reading	1/27/2024 12:00 AM

H. Report Notes and Comments