


A. Site Energy Production Summary

	Energy Production (kWh)			
	Site		By Turbine	
	P50 (Expected Production)	Actual Production	V1	V2
Dec-22	820,000	853,742	430,989	422,753
Jan-23	931,000	675,941	335,912	340,029
Feb-23	737,000	890,155	447,488	442,667
Mar-23	777,000	897,476	445,429	452,047
Apr-23	722,000	669,323	334,035	335,288
May-23	564,000	550,907	281,748	269,159
Jun-23	422,000	414,035	207,507	206,528
Jul-23	351,000	239,451	127,232	112,219
Aug-23	303,000	352,751	170,780	181,971
Sep-23	431,000	226,645	110,485	116,160
Oct-23	674,000	582,309	277,729	304,580
Nov-23	796,000	809,264	396,263	413,001
Dec-23	820,000	637,044	312,365	324,679
Production 2023 (ytd) (kWh)	7,528,000	6,945,301	3,446,973	3,498,328
Total Production (LTM) (kWh)	7,528,000	6,945,301	3,446,973	3,498,328
Capacity Factor (LTM)	26.43%			

B. Site Energy Production Graph

December-2023



Monthly Report
December-2023

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	1

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
June-2024	5.5 Year Maintenance	~8	V1
June-2024	5.5 Year Maintenance	~8	V1

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
12/12/2023	5 Year Maintenance	Planned	4.60	V1
12/12/2023	5 Year Maintenance	Planned	1.38	V2
12/13/2023	5 Year Maintenance	Planned	2.43	V2
12/13/2023	Blade Inspection	Unplanned	4.79	V1
12/26/2023-12/27/2023	Plant Shutdown	Unplanned	25.67	V1
12/26/2023-12/27/2023	Plant Shutdown	Unplanned	25.11	V2

F. Turbine Availability & Downtime*

Availability	This Month	Year To Date
V1	100.00%	99.89%
V2	100.00%	98.73%
Avg	100.00%	99.31%

Downtime (hr)	This Month	Year To Date
V1	35.06	113.18
V2	30.13	194.49
Total	65.19	307.67

G. Billed Data

Meter Reading (Date/Time)	1/1/2024 12:00 AM
Meter To Date Produced	38,078,621 kWh
Meter To Date Consumed	98,155 kWh
Last Reading Produced	37,459,909 kWh
Last Reading Consumed	97,091 kWh
Billed kWh	617,648 kWh
Next Meter Reading	2/1/2024 12:00 AM

H. Report Notes and Comments

* Due to expiration of the OEM warranty, turbine availability and downtime reporting will no longer include warrantied availability. Downtime will be categorized appropriately.