


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	L1	L2	L3
Jan-23	1,433,000	1,025,974	346,845	343,212	335,917
Feb-23	1,213,000	1,437,228	466,816	492,962	477,450
Mar-23	1,339,000	1,477,116	494,371	495,751	486,994
Apr-23	1,327,000	1,072,001	362,508	361,635	347,858
May-23	1,052,000	809,644	273,086	279,357	257,201
Jun-23	751,000	649,782	224,391	226,181	199,210
Jul-23	609,000	360,370	124,670	123,847	111,853
Aug-23	534,000	594,879	204,225	207,630	183,024
Sep-23	736,000	400,037	139,966	142,124	117,947
Oct-23	1,131,000	1,024,588	350,783	351,133	322,672
Nov-23	1,281,000	1,328,497	453,156	447,161	428,180
Dec-23	1,263,000	1,020,636	343,379	344,554	332,703
Jan-24	1,433,000	837,413	281,008	279,606	276,799
Production 2024 (ytd) (kWh)	1,433,000	837,413	281,008	279,606	276,799
Total Production (LTM) (kWh)	12,669,000	11,012,191	3,718,359	3,751,941	3,541,891
Capacity Factor (LTM)	27.86%				

B. Site Energy Production Graph

January-2024



Monthly Report
January-2024

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
March-2024	Goldwind 3.5 Year Maintenance	~8	L1
March-2024	Goldwind 3.5 Year Maintenance	~8	L2
March-2024	Goldwind 3.5 Year Maintenance	~8	L3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
1/8/2024-1/10/2024	Plant Shutdown	Unplanned	54.76	L1
1/8/2024-1/10/2024	Plant Shutdown	Unplanned	54.59	L2
1/8/2024-1/10/2024	Plant Shutdown	Unplanned	54.61	L3
1/22/2024-1/31/2024	Fleet Inspection Shutdown	Unplanned	226.6	L1, L2, L3

F. Turbine Availability & Downtime**

Availability	This Month	Year To Date
L1	100.00%	100.00%
L2	100.00%	100.00%
L3	100.00%	100.00%
Avg	100.00%	100.00%

Downtime (hr)	This Month	Year To Date
L1	281.36	281.36
L2	281.19	281.19
L3	281.21	281.21
Total	843.76	843.76

G. Billed Data

Meter Reading (Date/Time)	1/27/2024 12:00 AM
Meter To Date Produced	40,626,077 kWh
Meter To Date Consumed	129,817 kWh
Last Reading Produced	39,722,201 kWh
Last Reading Consumed	126,052 kWh
Billed kWh	900,111 kWh
Next Meter Reading	2/27/2024 12:00 AM

H. Report Notes and Comments

* Nov totals updated from the report published Jan 18, 2024 due to an error found in the SCADA data.
**Downtime beginning January 22, 2024 is classified under the 'Other' category due to an ongoing root cause investigation within the fleet; this classification may be subject to reallocation at a later date.