


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	WG1	WG2	WG3
Jan-23	1,343,000	1,022,726	364,829	333,353	324,544
Feb-23	1,133,000	1,357,316	469,593	443,298	444,425
Mar-23	1,312,000	1,397,327	483,104	451,227	462,996
Apr-23	1,272,000	971,079	347,951	314,716	308,412
May-23	974,000	666,913	244,432	206,831	215,650
Jun-23	714,000	586,809	200,667	193,800	192,342
Jul-23	566,000	447,128	154,258	148,599	144,271
Aug-23	514,000	508,391	179,206	161,643	167,542
Sep-23	716,000	353,349	120,898	111,723	120,728
Oct-23	1,051,000	833,613	294,717	274,789	264,107
Nov-23	1,224,000	1,145,351	403,047	369,056	373,248
Dec-23	1,217,000	968,195	337,648	315,435	315,112
Jan-24	1,343,000	834,692	299,854	288,942	245,896
Production 2024 (ytd) (kWh)	1,343,000	834,692	299,854	288,942	245,896
Total Production (LTM) (kWh)	12,036,000	10,070,163	3,535,375	3,280,059	3,254,729
Capacity Factor (LTM)	25.55%				

B. Site Energy Production Graph

January-2024



Monthly Report
January-2024

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
June-2024	5.5 Year Maintenance	~8	WG 1
June-2024	5.5 Year Maintenance	~8	WG 2
June-2024	5.5 Year Maintenance	~8	WG 3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
1/5/2024	Weather Shutdown	Unplanned	10.58	WG 3
1/19/2024-1/22/2024	Turbine Fault	Unplanned	61.02	WG 3
1/22/2024-1/31/2024	Fleet Inspection Shutdown	Unplanned	227.94	WG 1, WG 2, WG 3

F. Turbine Availability & Downtime*

Availability	This Month	Year To Date
WG1	100.00%	100.00%
WG2	100.00%	100.00%
WG3	100.00%	100.00%
Avg	100.00%	100.00%

Downtime (hr)	This Month	Year To Date
WG1	227.94	227.94
WG2	227.94	227.94
WG3	299.75	299.75
Total	755.63	755.63

G. Billed Data

Meter Reading (Date/Time)	1/29/2024 12:00 AM
Meter To Date Produced	56,637,480 kWh
Meter To Date Consumed	207,655 kWh
Last Reading Produced	55,750,232 kWh
Last Reading Consumed	203,009 kWh
Billed kWh	882,602 kWh
Next Meter Reading	2/29/2024 12:00 AM

H. Report Notes and Comments

* Due to expiration of the OEM warranty, turbine availability and downtime reporting will no longer include warrantied availability. Downtime will be categorized appropriately.

*Downtime beginning January 22, 2024 is classified under the 'Other' category due to an ongoing root cause investigation within the fleet; this classification may be subject to reallocation at a later date.