


A. Site Energy Production Summary

|                              | Energy Production (kWh) |                   |            |           |           |
|------------------------------|-------------------------|-------------------|------------|-----------|-----------|
|                              | Site                    |                   | By Turbine |           |           |
|                              | Expected Production     | Actual Production | WTG 1      | WTG 2     | WTG 3     |
| Feb-23                       | 1,170,349               | 1,453,948         | 522,598    | 439,412   | 491,938   |
| Mar-23                       | 1,227,217               | 1,298,079         | 501,593    | 304,805   | 491,681   |
| Apr-23                       | 1,438,497               | 1,155,788         | 408,089    | 343,589   | 404,110   |
| May-23                       | 980,450                 | 753,863           | 252,701    | 233,602   | 267,560   |
| Jun-23                       | 649,158                 | 683,362           | 231,589    | 228,457   | 223,316   |
| Jul-23                       | 618,687                 | 440,827           | 132,214    | 148,791   | 159,822   |
| Aug-23                       | 559,508                 | 555,831           | 128,322    | 211,051   | 216,458   |
| Sep-23                       | 603,085                 | 353,794           | 138,579    | 132,576   | 82,639    |
| Oct-23                       | 967,926                 | 1,001,240         | 338,432    | 337,485   | 325,323   |
| Nov-23                       | 1,362,692               | 1,373,200         | 473,833    | 450,348   | 449,019   |
| Dec-23                       | 1,254,397               | 1,184,353         | 403,749    | 399,895   | 380,709   |
| Jan-24                       | 1,290,968               | 1,381,482         | 471,543    | 462,558   | 447,381   |
| Feb-24                       | 1,170,349               | 1,107,267         | 415,523    | 340,449   | 351,295   |
| Production 2024 (ytd) (kWh)  | 2,461,317               | 2,488,749         | 887,066    | 803,007   | 798,676   |
| Total Production (LTM) (kWh) | 12,122,935              | 11,289,086        | 3,896,167  | 3,593,606 | 3,799,313 |
| Capacity Factor (LTM)        | 30.93%                  |                   |            |           |           |

B. Site Energy Production Graph February-2024



Monthly Report February-2024

C. Safety Summary

|                        | This Month | Project Cumulative |
|------------------------|------------|--------------------|
| Recordable Incident(s) | 0          | 0                  |
| Near Miss(es)          | 0          | 0                  |

D. Planned Maintenance Events

| Date     | Event                 | Duration (hr) | Turbine |
|----------|-----------------------|---------------|---------|
| May-2024 | 11.5 Year Maintenance | ~8            | WTG 1   |
| May-2024 | 11.5 Year Maintenance | ~8            | WTG 2   |
| May-2024 | 11.5 Year Maintenance | ~8            | WTG 3   |

E. Actual Maintenance Events

| Date                | Event             | Planned/Unplanned | Duration (hrs) | Turbine      |
|---------------------|-------------------|-------------------|----------------|--------------|
| 2/3/2024-2/4/2024   | Customer Shutdown | Unplanned         | 32.42          | WTG 1        |
| 2/3/2024-2/4/2024   | Customer Shutdown | Unplanned         | 31.77          | WTG 2, WTG 3 |
| 2/8/2024-2/12/2024  | Turbne Fault      | Unplanned         | 99.84          | WTG 2        |
| 2/24/2024           | Turbine Fault     | Unplanned         | 10.62          | WTG 3        |
| 2/25/2024-2/26/2024 | Turbine Fault     | Unplanned         | 26.88          | WTG 3        |
| 2/26/2024           | Turbine Fault     | Unplanned         | 7.63           | WTG 3        |
| 2/26/2024-2/27/2024 | Unknown Downtime  | Unplanned         | 20.61          | WTG 3        |

F. Turbine Availability & Downtime

| Availability | This Month | Year To Date |
|--------------|------------|--------------|
| WTG 1        | 100.00%    | 100.00%      |
| WTG 2        | 100.00%    | 100.00%      |
| WTG 3        | 100.00%    | 100.00%      |
| Avg          | 100.00%    | 100.00%      |

| Downtime (hr) | This Month | Year To Date |
|---------------|------------|--------------|
| WTG 1         | 4.13       | 37.00        |
| WTG 2         | 4.13       | 138.70       |
| WTG 3         | 4.15       | 102.78       |
| Total         | 12.41      | 278.48       |

G. Wind Speed & Capacity Factor

| Wind Speed (mph) | This Month | 2024 Annual |
|------------------|------------|-------------|
| WTG 1            | 4.94       | 4.94        |
| WTG 2            | 4.90       | 4.90        |
| WTG 3            | 4.97       | 4.97        |
| Estimated        | 17.02      | 13.39       |

| Capacity Factor (%) | This Month | 2024 Annual |
|---------------------|------------|-------------|
| WTG 1               | 39.80%     | 42.25%      |
| WTG 2               | 32.61%     | 41.45%      |
| WTG 3               | 33.65%     | 40.09%      |
| Low Estimate        | 29.98%     | 28.72%      |

H. Report Notes and Comments