




A. Site Energy Production Summary

		Energy Production (kWh)					
		Site		By Turbine			
		Expected Production	Actual Production	WTG A	WTG B		WTG C
	Feb-23	1,157,019	1,499,564	513,873	511,795	473,896	
	Mar-23	1,242,761	1,403,979	477,517	451,995	474,467	***
	Apr-23	1,447,248	1,194,254	398,085	398,085	398,085	*
	May-23	1,010,966	887,683	300,440	287,583	299,660	****
	Jun-23	668,411	610,504	240,557	117,217	252,730	
	Jul-23	638,097	331,312	124,906	135,529	70,877	
	Aug-23	577,992	642,748	209,098	212,029	221,621	
	Sep-23	631,697	463,267	154,792	153,657	154,818	
	Oct-23	1,003,602	1,091,106	381,773	348,712	360,621	
	Nov-23	1,395,914	1,358,931	475,875	461,556	421,500	
	Dec-23	1,278,858	1,094,994	354,430	371,945	368,619	
	Jan-24	1,332,437	1,291,710	437,812	434,202	419,696	
	Feb-24	1,157,019	1,212,723	415,829	388,526	408,368	
Production 2024 (ytd) (kWh)		2,489,456	2,504,433	853,641	822,728	828,064	
Total Production (LTM) (kWh)		12,385,000	11,583,211	3,971,114	3,761,036	3,851,062	
Capacity Factor (LTM)		29.30%					

B. Site Energy Production Graph

February-2024



Monthly Report
February-2024



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
June-2024	11.5 Year Maintenance	~8	WTG A
June-2024	11.5 Year Maintenance	~8	WTG B
June-2024	11.5 Year Maintenance	~8	WTG C

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
------	-------	-------------------	----------------	---------

F. Turbine Availability & Downtime**

Availability	This Month	Year To Date
WTG A	100.00%	100.00%
WTG B	100.00%	100.00%
WTG C	100.00%	100.00%
Avg	100.00%	100.00%

Downtime (hr)	This Month	Year To Date
WTG A	0	98.48
WTG B	0	97.78
WTG C	0	126.49
Total	0	322.75

G. Wind Speed & Capacity Factor

Wind Speed (mph)	This Month	2022 Annual
WTG A	12.72	13.03
WTG B	12.18	12.65
WTG C	13.26	13.49
Estimated	17.02	13.39

Capacity Factor (%)	This Month	2022 Annual
WTG A	39.83%	39.52%
WTG B	37.22%	38.09%
WTG C	39.12%	38.34%
Low Estimate	29.98%	28.72%

H. Report Notes and Comments

*Production read from the meter due to SCADA communication issues.

**Due to expiration of the OEM warranty, turbine availability and downtime reporting will no longer include warranted availability. Downtime will be categorized appropriately.

***March 2023 WTG Energy Production contains estimates due to a SCADA error. 3/30/2023 and 3/31/2023 are missing data for all 3 Turbines.

****May 2023 - 5/7/2023 and 5/8/2023 Production is from the meter due to a SCADA server error.