


A. Site Energy Production Summary

|                              | Energy Production (kWh)   |                   |            |           |           |
|------------------------------|---------------------------|-------------------|------------|-----------|-----------|
|                              | Site                      |                   | By Turbine |           |           |
|                              | P50 (Expected Production) | Actual Production | Z4         | Z5        | Z6        |
| Feb-23                       | 1,044,000                 | 1,259,079         | 420,192    | 393,112   | 445,775   |
| Mar-23                       | 1,119,000                 | 1,327,802         | 443,370    | 431,527   | 452,905   |
| Apr-23                       | 1,116,000                 | 979,332           | 324,138    | 323,000   | 332,194   |
| May-23                       | 876,000                   | 854,422           | 270,909    | 283,285   | 300,228   |
| Jun-23                       | 637,000                   | 690,482           | 226,931    | 231,165   | 232,387   |
| Jul-23                       | 518,000                   | 381,255           | 124,683    | 125,868   | 130,704   |
| Aug-23                       | 448,000                   | 542,148           | 181,375    | 178,264   | 182,509   |
| Sep-23                       | 617,000                   | 359,251           | 114,733    | 121,644   | 122,874   |
| Oct-23                       | 956,000                   | 879,647           | 289,457    | 284,843   | 305,347   |
| Nov-23                       | 1,107,000                 | 1,168,998         | 394,642    | 378,664   | 395,692   |
| Dec-23                       | 1,098,000                 | 967,377           | 303,513    | 327,543   | 336,321   |
| Jan-24                       | 1,251,000                 | 922,137           | 311,959    | 310,072   | 300,106   |
| Feb-24                       | 1,044,000                 | 0                 | 0          | 0         | 0         |
| Production 2023 (ytd) (kWh)  | 2,295,000                 | 922,137           | 311,959    | 310,072   | 300,106   |
| Total Production (LTM) (kWh) | 10,787,000                | 9,072,851         | 2,985,710  | 2,995,875 | 3,091,267 |
| Capacity Factor (LTM)        | 22.95%                    |                   |            |           |           |

B. Site Energy Production Graph

February-2024



Monthly Report

February-2024

C. Safety Summary

|                        | This Month | Project Cumulative |
|------------------------|------------|--------------------|
| Recordable Incident(s) | 0          | 0                  |
| First Aid              | 0          | 1                  |

D. Planned Maintenance Events

| Date       | Event                         | Duration (hr) | Turbine |
|------------|-------------------------------|---------------|---------|
| March-2024 | Goldwind 3.5 Year Maintenance | ~8            | Z4      |
| March-2024 | Goldwind 3.5 Year Maintenance | ~8            | Z5      |
| March-2024 | Goldwind 3.5 Year Maintenance | ~8            | Z6      |

E. Actual Maintenance Events

| Date               | Event                     | Planned/Unplanned | Duration (hrs) | Turbine |
|--------------------|---------------------------|-------------------|----------------|---------|
| 2/1/2024-2/29/2024 | Fleet Inspection Shutdown | Unplanned         | 696.00         | Z4, Z5  |
| 2/1/2024-2/29/2024 | Turbine Fault             | Unplanned         | 696.00         | Z6      |

F. Turbine Availability & Downtime\*\*

| Availability | This Month | Year To Date |
|--------------|------------|--------------|
| Z4           | 100.00%    | 100.00%      |
| Z5           | 100.00%    | 100.00%      |
| Z6           | 100.00%    | 100.00%      |
| Avg          | 100.00%    | 100.00%      |

| Downtime (hr) | This Month | Year To Date |
|---------------|------------|--------------|
| Z4            | 696        | 923.85       |
| Z5            | 696        | 923.87       |
| Z6            | 696        | 961.12       |
| Total         | 2088.00    | 2808.84      |

G. Billed Data

|                                    |                    |
|------------------------------------|--------------------|
| Meter Reading (Date/Time)          | 2/20/2024 12:00 AM |
| Ball 2.0 Production (This Period)  | 116,612 kWh        |
| Ball 2.0 Consumption (This Period) | 8,083 kWh          |
| Billed kWh                         | PENDING kWh        |
| Next Meter Reading                 | 3/20/2024 12:00 AM |

H. Report Notes and Comments\*\*

\*June 23 - June 25 Production is an estimate due to a SCADA server error.

\*\*Downtime beginning January 22, 2024 is classified under the 'Other' category due to an ongoing root cause investigation within the fleet; this classification may be subject to reallocation at a later date.

\*\*\*As a result of previously disclosed circumstances, the project has had no energy production since 01/22/2024.