


A. Site Energy Production Summary

		Energy Production (kWh)					
		Site		By Turbine			
		P50 (Expected Production)	Actual Production	Z4	Z5		Z6
	Mar-23	1,119,000	1,327,802	443,370	431,527	452,905	*
	Apr-23	1,116,000	979,332	324,138	323,000	332,194	
	May-23	876,000	854,422	270,909	283,285	300,228	
	Jun-23	637,000	690,482	226,931	231,165	232,387	
	Jul-23	518,000	381,255	124,683	125,868	130,704	
	Aug-23	448,000	542,148	181,375	178,264	182,509	
	Sep-23	617,000	359,251	114,733	121,644	122,874	
	Oct-23	956,000	879,647	289,457	284,843	305,347	
	Nov-23	1,107,000	1,168,998	394,642	378,664	395,692	***
	Dec-23	1,098,000	967,377	303,513	327,543	336,321	
	Jan-24	1,251,000	922,137	311,959	310,072	300,106	
	Feb-24	1,044,000	0	0	0	0	
	Mar-24	1,119,000	0	0	0	0	***
Production 2023 (ytd) (kWh)		3,414,000	922,137	311,959	310,072	300,106	
Total Production (LTM) (kWh)		10,787,000	7,745,049	2,542,340	2,564,348	2,638,362	
Capacity Factor (LTM)		19.59%					

B. Site Energy Production Graph

March-2024



Monthly Report
March-2024

C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	1

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
March-2024	Goldwind 3.5 Year Maintenance	~8	Z4
March-2024	Goldwind 3.5 Year Maintenance	~8	Z5
March-2024	Goldwind 3.5 Year Maintenance	~8	Z6

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
3/1/2024-3/31/2024	Fleet Inspection Shutdown	Unplanned	744.00	Z4, Z5
3/1/2024-3/31/2024	Turbine Fault	Unplanned	744.00	Z6

F. Turbine Availability & Downtime**

Availability	This Month	Year To Date
Z4	100.00%	100.00%
Z5	100.00%	100.00%
Z6	100.00%	100.00%
Avg	100.00%	100.00%

Downtime (hr)	This Month	Year To Date
Z4	744	1667.85
Z5	744	1667.87
Z6	744	1705.12
Total	2232.00	5040.84

G. Billed Data

Meter Reading (Date/Time)	3/20/2024 12:00 AM
Ball 2.0 Production (This Period)	- kWh
Ball 2.0 Consumption (This Period)	7,676 kWh
Billed kWh	PENDING kWh
Next Meter Reading	4/19/2024 12:00 AM

H. Report Notes and Comments**

*June 23 - June 25 Production is an estimate due to a SCADA server error.

**Downtime beginning January 22, 2024 is classified under the 'Other' category due to an ongoing root cause investigation within the fleet; this classification may be subject to reallocation at a later date.

***As a result of previously disclosed circumstances, the project has had no energy production since 01/22/2024.