



BALL CORPORATION - ZEPHYR WIND PROJECT 1.0

North Findlay Wind Campus, Findlay, OH

Monthly Report
April-2024




A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	P50 (Expected Production)	Actual Production	Z1	Z2	Z3
Apr-23	1,359,000	919,188	326,208	313,475	279,505
May-23	856,000	790,489	271,031	264,110	255,348
Jun-23	599,000	580,888	198,404	192,717	189,767
Jul-23	549,000	363,768	128,139	121,899	113,730
Aug-23	559,000	506,843	176,172	169,047	161,624
Sep-23	482,000	324,417	116,246	107,166	101,005
Oct-23	916,000	854,774	303,388	286,219	265,167
Nov-23	1,203,000	1,181,692	413,333	399,730	368,629
Dec-23	1,475,000	932,342	325,031	323,375	283,936
Jan-24	1,260,000	897,334	312,246	300,033	285,055
Feb-24	1,310,000	0	0	0	0
Mar-24	1,140,000	0	0	0	0
Apr-24	1,359,000	290,385	101,675	110,982	77,728
Production 2024 (ytd) (kWh)	5,069,000	1,187,719	413,921	411,015	362,783
Total Production (LTM) (kWh)	11,708,000	6,722,932	2,345,665	2,275,278	2,101,989
Capacity Factor (LTM)	17.01%				

B. Site Energy Production Graph

April-2024



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
First Aid	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
May-2024	8 Year Turbine Preventive Maintenance	~15	Z1
May-2024	8 Year Turbine Preventive Maintenance	~15	Z2
May-2024	8 Year Turbine Preventive Maintenance	~15	Z3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
4/1/2024-4/22/2024	Fleet Inspection Shutdown	Unplanned	512.82	Z1
4/1/2024-4/22/2024	Fleet Inspection Shutdown	Unplanned	512.88	Z2
4/1/2024-4/22/2024	Fleet Inspection Shutdown	Unplanned	512.87	Z3
4/23/2024-4/24/2024	Turbine Fault	Unplanned	21.81	Z1
4/27/2024-4/29/2024	Turbine Fault	Unplanned	43.16	Z3

F. Turbine Downtime¹

Downtime (hr)	This Month	Year To Date
Z1	537.66	2205.63
Z2	515.56	2183.24
Z3	558.71	2263.52
Total	1611.93	6652.39

G. Billed Data

Meter Reading (Date/Time)	4/19/2024 12:00 AM
Ball 1.0 Production (This Period)	0 kWh
Ball 1.0 Consumption (This Period)	6,886 kWh
Billed kWh	PENDING kWh
Next Meter Reading	5/18/2024 12:00 AM

H. Report Notes and Comments

¹ Turbine Availability/Downtime Pending.

² As a result of previously disclosed circumstances, the project has had no energy production Febraury 2024 - March 2024.