


A. Site Energy Production Summary

		Energy Production (kWh)				
		Site		By Turbine		
		P50 (Expected Prodution)	Actual Production	WG1	WG2	WG3
	Apr-23	1,272,000	971,079	347,951	314,716	308,412
	May-23	974,000	666,913	244,432	206,831	215,650
	Jun-23	714,000	586,809	200,667	193,800	192,342
	Jul-23	566,000	447,128	154,258	148,599	144,271
	Aug-23	514,000	508,391	179,206	161,643	167,542
	Sep-23	716,000	353,349	120,898	111,723	120,728
	Oct-23	1,051,000	833,613	294,717	274,789	264,107
	Nov-23	1,224,000	1,145,351	403,047	369,056	373,248
	Dec-23	1,217,000	968,195	337,648	315,435	315,112
	Jan-24	1,343,000	834,692	299,854	288,942	245,896
	Feb-24	1,133,000	0	0	0	0 2
	Mar-24	1,312,000	0	0	0	0
	Apr-24	1,272,000	165,611	81,100	0	84,511
Production 2024 (ytd) (kWh)		5,060,000	1,000,303	380,954	288,942	330,407
Total Production (LTM) (kWh)		12,036,000	6,510,052	2,315,827	2,070,818	2,123,407
Capacity Factor (LTM)		16.4	17%			

B. Site Energy Production Graph





Monthly Report April-2024



C. Safety Summary

	This Month	Project Cumulative	
Recordable Incident(s)	0	0	
First Aid	0	0	

D. Planned Maintenance Events

		Duration	
Date	Event	(hr)	Turbine
June-2024	5.5 Year Preventive Maintenance	~8	WG 1
June-2024	5.5 Year Preventive Maintenance	~8	WG 2
June-2024	5.5 Year Preventive Maintenance	~8	WG3

E. Actual Maintenance Events

		Planned/	Duration	
Date	Event	Unplanned	(hrs)	Turbine
4/1/2024-4/25/2024	Fleet Inspection Shutdown	Unplanned	593.02	WG1
4/1/2024-4/30/2024	Fleet Inspection Shutdown	Unplanned	720.00	WG 2
4/1/2024-4/25/2024	Fleet Inspection Shutdown	Unplanned	585.87	WG3
4/26/2024	Turbine Inspection	Unplanned	5.82	WG 1

F. Turbine Downtime¹

Downtime (hr)	This Month	Year To Date
WG1	598.84	2266.78
WG2	720.00	2387.94
WG3	585.87	2325.62
Total	1904.71	6980.34

G. Billed Data

Meter Reading (Date/Time)	4/29/2024 12:00 AM
Meter To Date Produced	56,758,812 kWh
Meter To Date Consumed	241,545 kWh
Last Reading Produced	56,637,480 kWh
Last Reading Consumed	207,655 kWh
Billed kWh	87,442 kWh
Next Meter Reading	5/29/2024 12:00 AM

H. Report Notes and Comments

¹ Turbine Availability/Downtime Pending.

² As a result of previously disclosed circumstances, the project had no energy production February 2024 - March 2024.

³ As a result of previously disclosed circumstances, WG 2 has had no energy production since 01/22/2024.