


A. Site Energy Production Summary

|                              | Energy Production (kWh) |                   |            |           |           |
|------------------------------|-------------------------|-------------------|------------|-----------|-----------|
|                              | Site                    |                   | By Turbine |           |           |
|                              | Expected Production     | Actual Production | WTG 1      | WTG 2     | WTG 3     |
| Jun-23                       | 649,158                 | 683,362           | 231,589    | 228,457   | 223,316   |
| Jul-23                       | 618,687                 | 440,827           | 132,214    | 148,791   | 159,822   |
| Aug-23                       | 559,508                 | 555,831           | 128,322    | 211,051   | 216,458   |
| Sep-23                       | 603,085                 | 353,794           | 138,579    | 132,576   | 82,639    |
| Oct-23                       | 967,926                 | 1,001,240         | 338,432    | 337,485   | 325,323   |
| Nov-23                       | 1,362,692               | 1,373,200         | 473,833    | 450,348   | 449,019   |
| Dec-23                       | 1,254,397               | 1,184,353         | 403,749    | 399,895   | 380,709   |
| Jan-24                       | 1,290,968               | 1,381,482         | 471,543    | 462,558   | 447,381   |
| Feb-24                       | 1,170,349               | 1,107,267         | 415,523    | 340,449   | 351,295   |
| Mar-24                       | 1,227,217               | 1,574,190         | 537,888    | 515,417   | 520,885   |
| Apr-24                       | 1,438,497               | 1,440,355         | 491,796    | 461,645   | 486,914   |
| May-24                       | 980,450                 | 836,173           | 284,799    | 275,439   | 275,935   |
| Jun-24                       | 649,158                 | 897,472           | 318,609    | 299,454   | 279,409   |
| Production 2024 (ytd) (kWh)  | 6,756,639               | 7,236,939         | 2,520,158  | 2,055,508 | 2,082,410 |
| Total Production (LTM) (kWh) | 12,122,935              | 12,146,184        | 4,135,287  | 4,035,108 | 3,975,789 |
| Capacity Factor (LTM)        | 30.73%                  |                   |            |           |           |

B. Site Energy Production Graph

June-2024



C. Safety Summary

|                        | This Month | Project Cumulative |
|------------------------|------------|--------------------|
| Recordable Incident(s) | 0          | 0                  |
| Near Miss(es)          | 0          | 0                  |

D. Planned Maintenance Events

| Date         | Event               | Duration (hr) | Turbine            |
|--------------|---------------------|---------------|--------------------|
| October-2024 | 12 Year Maintenance | ~8            | WTG 1 <sup>2</sup> |
| October-2024 | 12 Year Maintenance | ~8            | WTG 2 <sup>2</sup> |
| October-2024 | 12 Year Maintenance | ~8            | WTG 3 <sup>2</sup> |
| 1            |                     |               |                    |

E. Actual Maintenance Events

| Date                | Event      | Planned/Unplanned | Duration (hrs) | Turbine |
|---------------------|------------|-------------------|----------------|---------|
| 6/24/2024-6/28/2024 | Grid Fault | Unplanned         | 97.64          | WTG 1   |
| 6/24/2024-6/28/2024 | Grid Fault | Unplanned         | 96.66          | WTG 2   |
| 6/24/2024-6/28/2024 | Grid Fault | Unplanned         | 108.97         | WTG 3   |

F. Turbine Downtime <sup>1</sup>

| Downtime (hr) | This Month | Year To Date |
|---------------|------------|--------------|
| WTG 1         | 97.64      | 159.95       |
| WTG 2         | 96.66      | 249.02       |
| WTG 3         | 112.08     | 236.83       |
| Total         | 306.38     | 645.80       |

G. Wind Speed & Capacity Factor

| Wind Speed (mph)    | This Month | 2024 Annual |
|---------------------|------------|-------------|
| WTG 1               | 4.94       | 4.94        |
| WTG 2               | 4.90       | 4.90        |
| WTG 3               | 4.97       | 4.97        |
| Estimated           | 11.44      | 13.39       |
|                     |            |             |
| Capacity Factor (%) | This Month | 2024 Annual |
| WTG 1               | 29.50%     | 42.25%      |
| WTG 2               | 27.73%     | 41.45%      |
| WTG 3               | 25.87%     | 40.09%      |
| Low Estimate        | 17.87%     | 28.72%      |

H. Report Notes and Comments

<sup>1</sup> Turbine Availability/Downtime Pending.

<sup>2</sup> 11.5 Year Maintenance was completed in April 2024