


A. Site Energy Production Summary

	Energy Production (kWh)				
	Site		By Turbine		
	Expected Production	Actual Production	WTG A	WTG B	WTG C
Jun-23	668,411	610,504	240,557	117,217	252,730
Jul-23	638,097	331,312	124,906	135,529	70,877
Aug-23	577,992	642,748	209,098	212,029	221,621
Sep-23	631,697	463,267	154,792	153,657	154,818
Oct-23	1,003,602	1,091,106	381,773	348,712	360,621
Nov-23	1,395,914	1,358,931	475,875	461,556	421,500
Dec-23	1,278,858	1,094,994	354,430	371,945	368,619
Jan-24	1,332,437	1,291,710	437,812	434,202	419,696
Feb-24	1,157,019	1,212,723	415,829	388,526	408,368
Mar-24	1,242,761	1,577,430	527,008	516,861	533,561
Apr-24	1,447,248	1,470,775	495,877	478,795	496,103
May-24	1,010,966	862,575	288,229	287,713	286,633
Jun-24	668,411	942,158	314,570	308,308	319,280
Production 2024 (ytd) (kWh)	6,858,841	7,357,371	2,479,325	2,414,405	2,463,641
Total Production (LTM) (kWh)	12,385,000	12,339,729	4,180,199	4,097,833	4,061,697
Capacity Factor (LTM)	31.22%				

B. Site Energy Production Graph



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
November-2024	12 Year Maintenance	~15	WTG A
November-2024	12 Year Maintenance	~15	WTG B
November-2024	12 Year Maintenance	~15	WTG C

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
6/1/2024	Turbine Fault	Unplanned	4.05	WTG A
6/3/2024	11.5 Year Maintenance	Planned	5.87	WTG C
6/27/2024-6/28/2024	Turbine Fault	Unplanned	33.61	WTG A

F. Turbine Downtime ¹

Downtime (hr)	This Month	Year To Date
WTG A	46.86	160.61
WTG B	0.69	111.43
WTG C	7.08	143.01
Total	54.63	415.05

G. Wind Speed & Capacity Factor

Wind Speed (mph)	This Month	2022 Annual
WTG A	11.75	12.81
WTG B	11.47	12.53
WTG C	12.46	13.47
Estimated	11.44	13.39

Capacity Factor (%)	This Month	2022 Annual
WTG A	29.13%	37.84%
WTG B	28.55%	36.85%
WTG C	29.56%	37.60%
Low Estimate	17.87%	28.72%

H. Report Notes and Comments

¹ Turbine Availability/Downtime Pending.