


A. Site Energy Production Summary*

		Energy Production (kWh)					
		Site		By Turbine			
		P50 (Expected Production)	Actual Production	WTG 1	WTG 2		WTG 3
	Apr-24	1,335,000	696,296	320,266	107,262	268,768	3
	May-24	1,106,000	725,087	270,871	206,159	248,057	
	Jun-24	836,000	766,124	281,287	214,562	270,275	
	Jul-24	694,000	0				
	Aug-24	619,000	0				
	Sep-24	839,000	0				
	Oct-24	1,294,000	0				
	Nov-24	1,428,000	0				
	Dec-24	1,459,000	0				
	Jan-25	1,589,000	0				
	Feb-25	1,306,000	0				
	Mar-25	1,331,000	0				
	Apr-25	1,335,000	0				
Production 2024 (ytd) (kWh)		3,277,000	2,187,507	872,424	527,983	787,100	
Total Production (LTM) (kWh)		-	-	-	-	-	
Capacity Factor (LTM) ¹		- *Value calculated over the last 12 months					

B. Site Energy Production Graph

June-2024



C. Safety Summary

	This Month	Project Cumulative
Recordable Incident(s)	0	0
Near Miss(es)	0	0

D. Planned Maintenance Events

Date	Event	Duration (hr)	Turbine
Jul-24	500hour Maintenance	~20	WTG 1
Jul-24	500hour Maintenance	~20	WTG 2
Dec-24	Semi-Annual Maintenance	~8	WTG 3

E. Actual Maintenance Events

Date	Event	Planned/Unplanned	Duration (hrs)	Turbine
6/18/2024	500hour Maintenance	Planned	6.24	WTG 3

F. Turbine Downtime ²

Downtime (hr)	This Month	Year To Date
WTG 1	3.48	9.58
WTG 2	3.07	65.50
WTG 3	9.31	19.48
Total	15.86	94.56

G. Billed Data

Meter Reading (Date/Time)	7/1/2024 12:00 AM
Meter To Date Produced	2,161,413
Meter To Date Consumed	10,697
Last Reading Produced	1,407,575
Last Reading Consumed	7,070
Billed kWh	750,211 kWh
Next Meter Reading	8/1/2024 12:00 AM

H. Report Notes and Comments

¹ Capacity factor to be included once full year of data is available.

² Turbine Availability/Downtime Pending.

³ Turbines were actively generating starting these days:
WTG 1 - April 10
WTG 2 - April 18
WTG 3 - April 9
Energy generation was billed to the customer starting April 18, 2024